



OUTDOOR LIQUEFIED PETROLEUM GAS INSTALLATION REQUEST

Outdoor installations shall comply with NFPA 58 (2011 edition) and 2012 International Fire Code w/ City of Austin amendments.

APPLICANT INFORMATION	
Address:	Date of Request:
Applicant / Business Name:	
Applicant E-mail:	Applicant Telephone No.:
Owner's Agent:	
Owner's Agent E-mail:	Owner's Agent Telephone:
Property Owner or Owner's Agent Signature and Date	
PART 1 PROPERTY INFORMATION	
Provide the distance of the installation to the nearest property line.	FEET
Provide the distance of the installation to the closest occupied building on the lot.	FEET
Is the property immediately adjacent to undeveloped woodlands?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Does the property have any deed restriction prohibiting the aboveground or underground storage of hazardous materials on this property?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Property Zoning Designation:	
Lot Area:	ACRES
PART 2 STATIONARY CONTAINER AT ONE- & TWO- FAMILY DWELLINGS AND TOWNHOMES	
Provide the rated volume of the stationary container, measured in gallons water capacity.	GALLONS
Type of container installation	<input type="checkbox"/> Aboveground <input type="checkbox"/> Underground
Is there a fire hydrant located within 600 feet of the container? <i>(The distance is measured from the closest fire hydrant to front of the property + the distance from the front of the property to the stationary container.)</i>	<input type="checkbox"/> YES <input type="checkbox"/> NO
Is the single-family dwelling constructed as manufactured housing?	<input type="checkbox"/> YES <input type="checkbox"/> NO
PART 3 STATIONARY CONTAINER AT COMMERCIAL BUILDINGS	
Provide the rated volume of the stationary container, measured in gallons water capacity.	GALLONS
Indicate the number of stationary containers being installed.	
If two or more containers are installed will they be manifolded?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Select the type of installation	<input type="checkbox"/> Aboveground <input type="checkbox"/> Underground
Is there a fire hydrant located within 500 feet of the container? <i>The distance is measured from the closest fire hydrant to front of the property + the distance from the front of the property to the stationary container.</i>	<input type="checkbox"/> YES <input type="checkbox"/> NO
Select the type of service	<input type="checkbox"/> Vapor

Submit the LP-Gas Installation Request to the Austin Fire Department – Fire Marshal’s Office, 505 Barton Springs Road Suite 200, Austin, Texas 780704. E-mail: nathaly.richerson@austintexas.gov Facsimile: 512-974-0162



OUTDOOR LIQUEFIED PETROLEUM GAS INSTALLATION REQUEST

Outdoor installations shall comply with NFPA 58 (2011 edition) and 2012 International Fire Code w/ City of Austin amendments.

<i>For transfer of liquid installations provide a site map demonstrating compliance with distances to all exposures in NFPA 58 Table 6.5.2.1.</i>	<input type="checkbox"/> Transfer of Liquid <input type="checkbox"/> Motor Vehicle Fuel Dispensing
---	---

PART 4 CYLINDER EXCHANGE CABINET (CEC)

Number of Cabinets To Be Installed:	Number of Existing Cabinets:
Lbs. LP-Gas per Cylinder LBS	Number of Cylinders per CEC:
Total pounds LP-Gas in CEC LBS	Are cylinders for resale? <input type="checkbox"/> YES <input type="checkbox"/> NO
Is the CEC an automated cylinder exchange station? <input type="checkbox"/> YES <input type="checkbox"/> NO	

AUSTIN FIRE DEPARTMENT REVIEW

Review Results: <input type="checkbox"/> Approved <input type="checkbox"/> Approved With Comments <input type="checkbox"/> Denied	
City of Austin Site Plan Correction required? https://austintexas.gov/sites/default/files/files/Planning/Applications_Forms/29_site_plan_correction_form.pdf	<input type="checkbox"/> YES <input type="checkbox"/> NO
City of Austin Building Permit Required? http://www.austintexas.gov/department/building-plan-review	<input type="checkbox"/> YES <input type="checkbox"/> NO
Austin Fire Department Aboveground Hazardous Materials Permit Required? http://www.austintexas.gov/department/hazmat-permit	<input type="checkbox"/> YES <input type="checkbox"/> NO

TYPICAL FOR ALL INSTALLATIONS

- AFD shall inspect all underground installations prior to backfill the container. The backfill shall comply with NFPA 58 Section 6.6.6.1 (O).
- Container pressure relief devices shall be 10 feet from ignition sources (NFPA 58 Table 6.3.8)
- AFD shall inspect each stationary aboveground container prior to filling.

Review Comments

AFD Engineer:

- Cora Urgena, P.E., 512-974-0184; cora.urgena@austintexas.gov
- Yvonne Espinoza, P.E., 512-974-0185; yvonne.espinoza@austintexas.gov
- Scott Stookey, 512-974-0157; scott.stookey@austintexas.gov

LDC Zoning Designation:

AFD Box:

Updated 12-06-2016 per CLU comments/SAS

Submit the LP-Gas Installation Request to the Austin Fire Department – Fire Marshal’s Office, 505 Barton Springs Road Suite 200, Austin, Texas 780704. E-mail: nathaly.richerson@austintexas.gov Facsimile: 512-974-0162