

CITY OF AUSTIN STANDARD PRODUCTS LIST

for

PVC GRAVITY SEWER PIPE (18 INCH TO 60 INCH DIAMETER)

USING DEPARTMENT: Austin Water PREPARED BY: Bill Flynn, P.E. ISSUED: 05/25/83

REVISED BY: Jeff A. Kyle P.E. **REVISED:** 07/01/22

DESCRIPTION: Pipe, polyvinyl chloride (PVC) gravity sewer, 18-inch to 60-inch diameter meeting the following

requirements:

1. Pipe shall meet ASTM F679

2. Gasket joints shall meet ASTM D3212

3. Gaskets shall be Rieber-type, steel-reinforced elastomeric material meeting ASTM F477

4. Minimum pipe stiffness of 115 psi according to ASTM D2412

5. Maximum SDR of 26

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|-----------------|--|-----------------------------------|----------|
| 04/03/95 | WESTLAKE PIPE & FITTINGS (Formerly NAPCO / North American Pipe Co.) 2801 Post Oak Boulevard, Suite 410 Houston, TX 77056 | PS 115 See notes below | W. Flynn |
| 01/03/95 | JM EAGLE (Formerly J-M Pipe Manufacturing) Nine Peach Tree Hill Road Livingston, NJ 07039 | PS 115 See notes below | W. Flynn |
| 01/02/04 | DIAMOND PLASTICS CORPORATION P.O. Box 1608 Grand Island, NE 68802 | PS 115 See notes below | R. Lamb |
| 10/01/07 | NORTHERN PIPE PRODUCTS 1309 39th Street NW Fargo, ND 58102 | PS 115 See notes below | R. Lamb |
| 04/01/12 | JET STREAM (formerly Pipelife Jet Stream Inc.) 1700 South Lincoln Street Siloam Springs, AR 72761 | PS 115 See notes below | R. Lamb |
| 07/01/14 | VINYLTECH CORPORATION 201 South 61st Street Phoenix, AZ 85043 | PS 115 See notes below | R. Lamb |

NOTES:

- 1. For each project, Design Engineer shall submit to Austin Water, deflection calculations based upon actual installation conditions as required by TCEQ rules. Installations will be considered for approval on a case-by-case basis.
- 2. Pipe with a whitened exterior (fading of color) that was manufactured more than two (2) years before the proposed installation date shall be rejected.
- 3. Deflection testing is required and shall be conducted after final backfill has been in place at least 30 days. A rigid mandrel shall be used. Mandrel sizes are shown below.



CITY OF AUSTIN STANDARD PRODUCTS LIST

for

PVC GRAVITY SEWER PIPE (18 INCH TO 60 INCH DIAMETER)

| | | Pipe Stiffness 115 psi | |
|--------------|--------------|------------------------|-------------|
| Nominal | Average | Minimum Wall | 95% Mandrel |
| Size, inches | O.D., inches | Thickness, | Diameter, |
| | | inches | inches |
| 18 | 18.701 | 0.671 | 16.49 |
| 21 | 22.047 | 0.791 | 19.44 |
| 24 | 24.803 | 0.889 | 21.87 |
| 30 | 32.000 | 1.148 | 28.22 |
| 36 | 38.300 | 1.373 | 33.78 |
| 42 | 44.500 | 1.596 | 39.24 |
| 48 | 50.800 | 1.822 | 44.80 |
| 54 | 57.560 | 2.064 | 50.76 |
| 60 | 61.610 | 2.210 | 54.33 |

LATEST REVISIONS (since 1/1/20):

- 1. Expanded allowable sizes to include up to 60" diameter pipe.
- 2. Updated NAPCO / North American Pipe Co. to Westlake Pipe & Fittings.
- 3. Updated Pipelife Jet Stream Inc. to Jet Stream, and updated company mailing address.