



Hydrant Mounted Water Meter Permit

The permit is valid for **1 year** from installation and will automatically expire. If water is still needed, the customer must reapply for a hydrant water meter prior to this permit expiration. The City requires that an approved reduced pressure backflow prevention assembly (RPZ) be installed and certified by a State of Texas-licensed backflow prevention assembly tester (BPAT) registered with Austin Water prior to obtaining water from a fire hydrant-mounted meter.

Applicant/Company Information

Billing Legal Name: _____

Billing Address: _____

Office Contact Name: _____ Office Phone: _____

On Site Contact: _____ Cellular #: _____

Project Name: _____ Email: _____

Applicant/Company: (circle one) Corporation Partnership Sole Proprietorship Other: _____

Federal Tax ID # or other ID (Required): _____

Meter, Service Address and Usage Information (City does not provide backflow prevention assembly)

Meter Size Requested: **1" / 3"** (deposit required for either meter size)

Deposit, installation & initiation fees will bill on the first utility bill statement.

Fire Hydrant address: _____

Specific use of water: _____

Is water intended for potable purposes? (Check one) Yes _____ No _____

If water will be used for potable purposes at any time during the permit life, the customer must contact Special Services Division (SSD) Water Protection Section at 512-972-1060 to schedule a cross connection survey BEFORE using the water for potable purposes.

Will hydrant meter be connected to a private fire hydrant? (Check one) Yes _____ No _____

A private fire hydrant owner's written authorization to use the private fire hydrant must accompany this application.

Signatory Requirements -

*This permit must be signed by an authorized representative of the Applicant as described herein. For a corporation, this permit shall be signed by a responsible corporate officer. A responsible corporate officer means a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation. For a partnership or sole proprietorship, this permit shall be signed by a general partner or the proprietor, respectively. **In signing, I certify that I am an authorized representative of the Applicant:***

Applicant Signature

Title

Date

Signature releases the City of Austin and applicant agrees to hold harmless and defend the City of Austin from any claims from any and all liability and losses for personal injury or property damage resulting from applicant's use of a fire hydrant. This form becomes the permit upon signature by the applicant and assignment of a billing account by Austin Water personnel. The permit holder must keep a copy of the permit in any vehicle used to withdraw the water. The permittee is liable for any damages to the City hydrant or infrastructure due to misuse or improper operation of the hydrant.

Applications may be submitted:

- In the Taps Office: 625 E. 10th Street, Suite # 200 during office hours (8 a.m. – 11:30 a.m. Monday – Friday)
- By fax at 512-972-0024 or by email at AWTaps@austinwater.com

OFFICE USE ONLY

Company Name: _____

Premise Address: _____

Account # _____ Person Picking up Casing: _____

Hydrant ID# _____ Casing Number _____

Grid # _____ Map Pg # _____

SR Type	SR#	Date	Meter #	Meter Read
Install				
Remove				

Truck Mounted Meter Permit Process

A. Fire hydrant-mounted meter and backflow protection:

The City requires that an approved reduced pressure backflow prevention assembly (RPZ) be installed and certified by a State of Texas-licensed backflow prevention assembly tester (BPAT) registered with the Austin Water Utility prior to obtaining water from a fire hydrant-mounted meter. Permittee is allowed 15 minutes to complete backflow test and put in service. Permittee may be asked to reschedule and pay additional meter installation fee for any additional length of time after the required 15 minutes.

At the scheduled appointment with the City's meter setter and at the permittee's expense, the permittee shall:

1. Mark the hydrant to be used with flagging.
2. Have an RPZ properly installed, braced, and supported immediately downstream of the meter so as to prevent damage to the hydrant and meter.
3. Have the RPZ tested by a City-registered and State-licensed BPAT.
4. Furnish a current and passing Test and Maintenance Report (TMR) to the City's meter setter.

Note: City personnel will remove any meter found attached to a hydrant without bracing or an approved RPZ. Such action is a violation of the Austin City Code and will result in enforcement actions taken against the permittee, including the forfeiture of the permittee's deposit. Rescheduling of appointment will incur additional non-compliance fee.

B. Backflow Prevention Assembly Technician List

1. Customers can request a printed copy of the registered and licensed backflow prevention assembly technicians by calling 512-972-1060.

C. Email AWTaps@austintexas.gov to request a Service Request number (SR#) for meter installation.

D. After receiving the approved permit (SR#), the permittee shall email the Austin Water Meter Shop ("Meter Shop") at awmtrshop@austintexas.gov to make an appointment for the installation of a meter on a fire hydrant. The permittee must arrive on time to the scheduled appointment. **Permit holders who arrive more than 15 minutes late will be required to reschedule and pay a second meter installation fee. Permit holders who do not have the required meter assembly installed or fail the backflow assembly test, will be required to pay a non-compliance fee. Permit will be cancelled if appointment is not scheduled in 30 days.**

E. A non-refundable installation and initiation charge will be billed on the permittee's first billing statement.

F. Unless otherwise authorized by the Director of the Austin Water, the water meter shall be used for construction purposes only.

G. The permittee is solely responsible for the fire hydrant-mounted meter assembly until the Meter Shop personnel remove the meter. The permittee will be required to reimburse the City of Austin ("City") for the cost of the meter and meter parts, if the permittee fails to request the City to remove the meter or if loss, damage, or theft of meter or meter parts occurs.

H. Removal of fire hydrant-mounted water meter

1. The permittee is allowed to remove a fire hydrant-mounted meter at any time; such action is a violation of the Austin City Code and will result in an enforcement action taken against the permittee, including the forfeiture of the permittee's deposit.
2. The Meter Shop personnel shall disconnect and remove the meter upon the permittee's request, completion of construction, installation of permanent water meter, or expiration of the permit, whichever occurs first. The permittee is required to contact the Taps Office (512-972-0000 or AWTaps@austintexas.gov) within two weeks of the permit expiration date to arrange for meter removal. The permittee will be required to reimburse the Austin Water Utility for the cost of the meter and meter parts, if the permittee fails to request Austin Water to remove the meter or if loss, damage, removal or theft of meter or meter parts occurs.

Fire Hydrant Operating Procedures

1. The permittee is responsible for following these procedures and may be held liable for repairs, and be subject to other enforcement actions for not adhering to these procedures.
2. Prior to operation, the permittee shall verify that the hydrant and meter are secure and not moveable, and in the event that they are unstable, damaged, leaking, or unsafe, should immediately stop using them and call Dispatch at 512-972-1000 to report the situation.
3. The permittee shall a) use a fire hydrant wrench specifically designed and manufactured to open and close a fire hydrant; b) not use any additional torquing device to open or close a fire hydrant; and c) not leave hoses or appurtenances connected to a fire hydrant when not in use.
4. The permittee shall operate a fire hydrant properly by slowly opening the hydrant to a fully open position when in use and slowly closing the hydrant to a completely closed position when not in use. When a fire hydrant is first opened, the barrel or housing of the fire hydrant fills with water. Fire hydrants are designed with a drain or weep hole at the base of the hydrant, which allows any water contained in the hydrant to drain out to keep:
 - a) the water from stagnating in the barrel of the hydrant,
 - b) the internal parts of the hydrant from rusting or seizing up, and
 - c) the hydrant from freezing in winter. A hydrant operated in a partially opened or closed position will cause water to blow out from the hydrant's drain or weep hole into the bedding material supporting the hydrant. This blown out water will wash out the bedding material supporting the hydrant thus possibly causing damage to the hydrant and creating a safety hazard.
5. The hydrant must be opened slowly to allow the barrel time to fill, and the permittee should feel snug resistance at the top of the counter clockwise turn. The permittee should not use the hydrant until it is fully opened.
6. To close the hydrant, the permittee must perform the final several closing turns slowly to prevent damage to the hydrant and water main. The hydrant must be fully closed until the permittee can feel snug resistance at the bottom of the clockwise turn.
7. To minimize wear and tear, and minimize costly damage due to the opening and closing of hydrants, the permittee may not use the hydrant valve to regulate the volume or flow of water withdrawn from the fire hydrant. Instead,
 - a. For fire hydrant-mounted meters, the permittee shall leave hydrants open during times of routine use unless there is danger of freezing and control the volume or flow of water withdrawn from the hydrant using the gate valve installed by the City on the meter

SPECIFICATIONS FOR 3" FIRE HYDRANT-MOUNTED METERS

These specifications are in compliance with the latest revision of AWWA Standard C701 with certain exceptions as noted below. All specifications meet or exceed the latest revision on AWWA C701.

TYPE

Meters shall be of the in-line horizontal-axis high velocity type per AWWA Class II and designed for mobile use in metering flow from fire hydrants.

OPERATING CHARACTERISTICS

The capacity of the meter in terms of normal operating range, maximum loss of head, and maximum continuous flow shall be as shown below:

<i>Accuracies</i>				<i>+/-1.5%</i>	<i>+2/-5%</i>
<u>Size</u>	<u>Normal Operating Range (gpm)</u>	<u>Max. Head Loss at Cont Flow (psi)</u>	<u>Max. Cont. (gpm)</u>	<u>Max. Capacity (gpm)</u>	<u>Extended Low Flow</u>
3"	5 - 660	37 w/integral strainer	450	660	4

SIZE

The size of the meter shall be determined by the nominal size (in inches) of the opening in the inlet and outlet flanges. Overall lengths of the meter shall be as follows:

Max. Meter Height from		
<u>Size</u>	<u>Laying Length</u>	<u>Bottom to Top of Handles</u>
3"	12" less couplings 17" with couplings	9"

EXTERNAL BOLTS

Casing bolts shall be made of type 316 stainless steel.

OPTIONAL CONNECTIONS

Maincase shall be equipped with a standard brass female swivel fire hose coupling assembly on the inlet side and a standard brass male hose coupling on the outlet side.

An additional option with the Connections shall be a brass close nipple mounted to the outlet side of the meter with 2" gate valve and then the standard brass male hose coupling.

CASE AND COVER

The maincase shall be cast aluminum and the cover of the head assembly cast bronze. The size, model, manufacturer's trademark, statement "AWWA Class II", and arrows indicating direction of flow shall be cast in raised characters on both sides of the maincase.

The size and arrows indicating direction of flow shall be cast in raised characters on the housing cover. The cover shall contain a calibration mechanism for the purpose of calibrating the turbine measuring element while in-line and under pressure. The calibration mechanism shall be mounted under the register and be covered by a protective cap.

The case shall be equipped with replaceable dual handles for ease of carrying, installation and maintenance.

REGISTERS

Registers shall be permanently roll sealed, straight reading, indicating in gallons, cubic feet, or cubic meters. Registers shall include a center-sweep test hand, a low flow indicator, meter size, model designation representing maximum continuous flow and a glass lens. Register shall be serviceable without interruption of the meter's operation.

REGISTER BOX

Register boxes and covers shall be of bronze composition. No plastic retainer rings will be acceptable. The name of the manufacturer, manufacturer trademark and the meter serial number shall be clearly identifiable and located on the register box cover.

REGISTER BOX SEALING

The register box shall be secured to meter bayonet with a tamper resistant seal screw. Options: Seal wire screw or Torx® seal screw. Register lid must have a locking design.

METER SERIAL NUMBER

The meter serial number shall be imprinted on the meter main case or cover as well as the register box cover.

UNITIZED MEASURING ELEMENT

The turbine measuring chamber shall be a self-contained unit attached to the cover for easy field removal. The turbine spindles shall be stainless steel. The rotor shall balance or "float" between the turbine spindles throughout the typical operating range.

INTERMEDIATE GEAR TRAIN

The intermediate gear train shall be directly-coupled to the rotor spindle and magnetically coupled to the register through the meter cover. The gear train shall be continuously submerged by the use of a vent tube which eliminates entrained air in the cover. All moving parts of the gear train shall be made of a self-lubricating polymer or stainless steel for operation in water.

STRAINERS

The fire hydrant meter shall contain a double walled stainless steel screen in the inlet end of the meter housing. The strainer shall be easy to remove for routine cleaning.

ORIFICE

The fire hydrant meter shall contain a permanent orifice design built into the outlet end of the meter housing. The orifice shall limit the maximum capacity to 660gpm for protection of the measuring element.

PERFORMANCE

Registration accuracy over the normal operating range shall be 98.5% to 101.