



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
AIR RELEASE/VACUUM RELIEF VALVES FOR WASTEWATER

USING DEPARTMENT: Austin Water **PREPARED BY:** Bill Flynn, P.E. **ISSUED:** 07/01/88
REVISED BY: Jeff A. Kyle, P.E. **REVISED:** 01/01/20

DESCRIPTION: Air release (combination, automatic)/vacuum relief valve for wastewater service only, size and optional features to be shown on approved engineering drawings. All components shall be 316 stainless steel. The minimum pressure rating shall be 250 psi.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/03/95	VAG-USA (GA Industries) 9025 Marshall Road Cranberry Township, PA 16066	942SS	W. Flynn J. Kyle
07/03/95	DEZURIK 250 Riverside Ave N Sartell, MN 56377	ASU Combination AV*	W. Flynn J. Kyle
07/03/95	VAL-MATIC VALVE & MFG. CORP 905 Riverside Drive Elmhurst, IL 60126	802-ASX	W. Flynn J. Kyle
07/01/96	MULTIPLEX MFG. CO/CRISPIN P.O. Box 427 Berwick, PA 18603	UX-20 Series*	W. Flynn J. Kyle
10/01/03	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-26 (2"-8")	R. Lamb J. Kyle
10/01/19	H-TEC 1061 Triad Court, West Oak Business Park II, Ste. 5 Marietta, GA 30062	Models 986 & 988	J. Kyle

NOTES:

- *Must specify 300 psi unit in order

LATEST REVISIONS:

- Revised ARI Flow Control from D-025 to D-26.