



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
PVC WASTEWATER LINE FITTINGS**

USING DEPARTMENT: Water Utility **ISSUED:** 09/09/81 **REVIEWED:** 04/01/10 **REVISED:** 04/01/10

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Fittings, polyvinyl chloride (PVC) gravity sewer, meeting ASTM D3034 with minimum stiffness of 115 psi or meeting ASTM F679 with minimum stiffness of 75 psi and with elastomeric gasket joints meeting ASTM F1336 and gaskets meeting ASTM F477. (10" fittings for maintenance only.)

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/96	TIGRE USA, INC. (formerly Vassallo) 2315 Beloit Avenue Janesville, WI 53546	ASTM D3034 or F679 Includes D3034 6" two-way cleanout fitting See notes below	K. Flowers
01/04/99	THE HARRINGTON CORP. P.O. Box 10335 Lynchburgh, VA 24506	Marked "HARCO" (fittings are gray) ASTM D3034 Includes Part No. 313-0806 for wastewater services connecting to AWWA C900 DR 14 PVC wastewater mains. See SPL WW-227D. (fitting is white) See notes below	K. Flowers
07/01/98	PLASTIC TRENDS, INC. P.O. Box 64000 Detroit, MI 48264	ASTM D3034 See notes below Includes 6" two-way cleanout fitting Includes 4" two-way cleanout fitting (Part No. H1004)	K. Flowers
10/01/98	GPK PRODUCTS, INC. 1601 43 rd Ave. Fargo, ND 58102	ASTM D3034 or F679 Includes 4" two-way cleanout fitting (Part No. 993-0444) See notes below	K. Flowers
01/04/99	MULTI-FITTINGS CORPORATION 4507 LeSaint Ct. Fairfield, OH 45014	ASTM D3034 with Multi-Loc gaskets, Includes 6" two-way cleanout fitting. See notes below	K. Flowers
01/02/98	SPECIFIED FITTINGS, INC. P.O. Box 28157 Bellingham, WA 98226	ASTM D3034 or F679 12" larger body size only. See notes below	K. Flowers

NOTE:

1. Acceptable fitting sizes are 6" minimum (service laterals only), 8", 12", 15", 18", 21", and 24".
2. All joint gaskets shall be secured in place.