CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
BALL VALVES FOR PROPERTY OWNER'S CUT OFF

USING DEPARTMENT: Water Utility **ISSUED:** 07/01/02 **REVIEWED:** 10/01/12 **REVISED:** 10/01/12

PREPARED BY: David Rinn **CITY STOCK NUMBER:**

DESCRIPTION: Valves, Ball, with stainless steel handles, used on meter nipple for property owner's cut off. Conforms to specification MSS-SP-110. Threaded ends comply with ANSI B2.1CSA/AGA/CGA certified. All valves shall be full port with chrome-plated bronze ball. Effective January 1, 2013, valves purchased for City forces shall be "lead free" and marked by stamping, etching, or casting "NL" in the main body or by other methods acceptable to City. Effective January 4, 2014, all valves must be "lead free."

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
07/01/02	MIDLAND METAL MFG 2021 Forest Ave. Kansas City, MO 64108	IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle and nut ¾" – 948-154ST 1" – 948-155ST	K. Flowers
07/01/02	NIBCO P.O. Box 1167 Elkhart, IN 46515-1167	IPS ball valves, full port, SWP 600 CWP with stainless steel lever handle and nut (use only in rectangular or square valve box providing clearance for handle) ¾" – T-585-70-SSHN 1" – T-585-70-SSHN 1½" − T-585-70-SSHN 2" − T-585-70-SSHN	R. Lamb
07/01/04	MATCO-NORCA P.O. Box 27 Route 22 Brewster, NY 10509	IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle, nut and washer ¾" – 759T04TS 1" – 759T05TS	R. Lamb
07/01/04	WEBSTONE CO., INC. P.O. Box 59 Worchester, MA 01613	IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle, nut and washer ¾" – 41703SSW 1" – 41704SSW 1½" − 41706SSW 2" − 41707SSW	R. Lamb
07/01/05	B & K (MUELLER) INDUSTRIES, INC. 2600 Elmhurst Road Elk Grove, IL 60007	¾" and 1" IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle ¾" – 107-824 T 1" – 107-825 T	R. Lamb

NOTE: