



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
COMPACT DUCTILE IRON FITTINGS**

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/87 **REVIEWED:** 01/01/12 **REVISED:** 01/01/12

PREPARED BY: William Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Fittings, Compact Ductile Iron complying with AWWA C153 in 4", 6", 8", 12", 16", 20" and 24" sizes. All fittings shall have markings cast on the body as required by AWWA C153. Fittings complying with AWWA C153 shall be asphalt coated and cement-mortar lined with asphaltic seal coat complying with AWWA C104, or fusion-bonded epoxy coated and lined (inside and outside) complying with AWWA C116. Fusion-bonded epoxy must be red and shall comply with requirements of NSF 61. (See SPL WW-27 for Ductile Iron Fittings complying with AWWA C110.)

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|---------------------|--|--|-----------------|
| 07/01/98 | TYLER PIPE CO. P.O. Box 2027 Tyler, TX 75710 | All Series; no retainer glands | W. Flynn |
| 01/02/98 | US PIPE AND FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202 | All Series | W. Flynn |
| 10/01/97 | A-1 FOUNDRY (China)/ SIGMA CORPORATION P.O. Box 300 Rt. 537 Goldman Road Cream Ridge, NJ 08514 | All Fittings | W. Flynn |
| 01/02/98 | UNION FOUNDRY CO./DIVISION OF McWANE P.O. Box 309 Anniston, AL 36202 | All Series | W. Flynn |
| 04/01/97 | SOMEPI (SMP/BRAZIL)/ STAR PIPE PRODUCTS 4018 Westhollow Pkwy. Houston, TX 77082 | All Fittings | W. Flynn |
| 04/03/95 | GRIFFIN PIPE PRODUCTS CO 2601 Ninth Ave Council Bluffs, IA 51501 | All Series | W. Flynn |
| 07/01/96 | INFACOT CORP. 7555 Caney Fork Rd. Fairview, TX 37062 | Foster Adaptor bolt-through MJ restraint (Use nuts recommended by manufacturer) | W. Flynn |



**CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
COMPACT DUCTILE IRON FITTINGS**

USING DEPARTMENT: Water Utility **ISSUED:** 10/01/87 **REVIEWED:** 01/01/12 **REVISED:** 01/01/12

PREPARED BY: William Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Fittings, Compact Ductile Iron complying with AWWA C153 in 4", 6", 8", 12", 16", 20" and 24" sizes. All fittings shall have markings cast on the body as required by AWWA C153. Fittings shall be asphalt coated and cement-mortar lined with asphaltic seal coat complying with AWWA C104, or fusion-bonded epoxy coated and lined (inside and outside) complying with AWWA C116. Fusion-bonded epoxy must be red and comply with requirements of NSF 61. (See SPL WW-27 for Ductile Iron Fittings complying with AWWA C110.)

| LISTING DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT | APPROVAL |
|---------------------|---|--|-----------------|
| 01/02/03 | AMERICAN FLOW CONTROL P.O. Box 2727 Birmingham, AL 35202-2727 | 4" to 12" | R. Lamb |
| 04/01/04 | ONE BOLT, INC. 169 Cahaba Valley Pkwy Pelham, AL 35124 | Fittings with integral joint restraint, water application only, 4" to 12" Black retainer gland for DI pipe Red retainer gland for PVC pipe | R. Lamb |
| 04/01/09 | ASSURED FLOW SALES, INC. P.O. Box 49633 Sarasota, FL 34230 | Gradelok | R. Lamb |
| 04/01/10 | SHANXI YUANSHENG (China)/ ACCUCAST 415 S. 21 st Ave. Waco, TX 76706 | 4" to 12"  Foundry Logo on Casting | R. Lamb |
| 01/01/12 | METALFIT (MEXICO) METALFIT 5583 Snowflake Way Parker, CO 80134 | All Fittings Markings include Griffin or Metalfit | R. Lamb |

NOTE: