



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
RESILIENT-SEATED GATE VALVES, AWWA C509

USING DEPARTMENT: Water Utility **ISSUED:** 04/28/78 **REVIEWED:** 01/01/11 **REVISED:** 01/01/11

PREPARED BY: David Rinn **CITY STOCK NUMBER:**

DESCRIPTION: Resilient-Seated Gate Valves, AWWA C509. (4" through 16") Non-rising stem having end types with gaskets, glands bolts, etc. as requisitioned. Copper alloy parts (bronze or brass) shall contain not over 16 percent zinc. Copper alloy UNS No. shall be shown on permanent external marking in addition to markings required by AWWA C509. Valve stems shall turn clockwise to close.

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/28/78	CLOW CORPORATION/VALVE DIV. P.O. Box 350 Oskaloosa, IA 52577	R/W (4" – 12")	K. Flowers
04/03/95	MUELLER COMPANY 500 West Eldorado St. Decatur, IL 62525	Series A-2360 City of Austin Model E-301 Tapping Valve T-2360 (4" – 16")	K. Flowers
07/01/98	U.S. PIPE AND FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	Metroseal 250 (4" – 12") 16" for Water Distribution and Wastewater Collection Service only.	K. Flowers
01/03/94	AMERICAN FLOW CONTROL P.O. Box 2727 Birmingham, AL 35207	AFC-500 Series (4" – 12")	K. Flowers
04/01/94	AMERICAN AVK CO. 5286 East Home Ave. Fresno, CA 93727	Series 25 R/W (4" – 16") Bronze or Stainless Steel Valve Stems	R. Lamb
01/03/95	KENNEDY VALVE Division of McWane, Inc. 1021 East Water Street Elmira, NY 14902-1516	4" – 12"	K. Flowers
10/01/96	M & H VALVE Division of McWane, Inc. P.O. Box 2088 Anniston, AL 36202	4" – 12"	K. Flowers

NOTE:

1. Specifying or use of valves outside the indicated size range requires approval of the Austin Water Utility on a project-by-project basis.
2. Contractor's/manufacturer's PROJECT submittal for valves larger than 24" diameter, when approved for use, shall include catalogue drawings and assembly drawings (shop drawings) specific to valves required for the project.
3. All valves 24" and larger shall be geared.