CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
CONCRETE STEEL CYLINDER PIPE

USING DEPARTMENT: Water Utility **ISSUED:** 04/28/78 **REVISED:** 10/01/04

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Pipe, concrete steel cylinder: AWWA C-301 (any size)
AWWA C-303 (24" maximum diameter: not permitted in easements on private property)

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/28/78	HANSON CONCRETE PRODUCS P.O. Box 47470 Dallas, TX 75247	See notes	W. Flynn
07/01/97	PRICE BROTHERS CO. 2133 Silverside Drive Suite E Baton Rouge, LA 70808	See notes AWWA C-301 Pipe	W. Flynn
01/02/97	CRETEX PRESSURE PIPE, INC. 123 East Lake Street Suite 204 Bloomingdale, IL 60108	See notes AWWA C-301 Pipe	W. Flynn

NOTE:

1. For pipe larger than 24" diameter, manufacturer must provide one of the following with project submittal: a) evidence of current ISO registration, b) evidence of current Austin Water Utility-approved quality control program, or c) name and qualifications of independent, third party firm that will test and inspect pipe produced for City of Austin, as per Standard Specification Item 510.