



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for
PVC WATER PIPE (4-INCH TO 12-INCH DIAMETER)

USING DEPARTMENT: Water Utility **ISSUED:** 05/10/84 **REVIEWED:** 01/01/10 **REVISED:** 01/01/10

PREPARED BY: Bill Flynn, P.E. **CITY STOCK NUMBER:**

DESCRIPTION: Pipe, polyvinyl chloride (PVC), 4" through 12" cast iron pipe size O.D. with elastomeric gasket joints for water service. AWWA C-900 current, PR 305 psi (DR14).

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
11/30/84	JM EAGLE (formerly J-M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039	See notes below	W. Flynn
10/01/96	CERTAINTED CORPORATION P.O. Box 860 Valley Forge, PA 19482	See notes below Includes Certa-Lok restrained joint pipe	R. Lamb
04/01/93	NORTH AMERICAN PIPE CORPORATION 2801 Post Oak Boulevard Suite 410 Houston, TX 77056	See notes below	W. Flynn
04/02/90	DIAMOND PLASTICS CORPORATION P.O. Box 2748 Lubbock, TX 79408-2748	See notes below	W. Flynn
10/01/05	VINYLTECH CORPORATION 201 South 61st Avenue Phoenix, AZ 85043	See notes below	R. Lamb
10/01/07	NORTHERN PIPE PRODUCTS 1309 39th Street NW Fargo, ND 58102	See notes below	R. Lamb

NOTE:

1. Material must comply with requirement of description above and be rated above design pressure. Acceptable sizes are 4", 6", 8" and 12".
2. City of Austin Specifications prohibits the use of AWWA C900 water pipe in easements on private property, for wastewater force mains or for conveyance of anything but potable water.