



**CITY OF AUSTIN  
STANDARD PRODUCTS LIST  
for  
VENTILATION PIPE**

**USING DEPARTMENT:** Water Utility

**ISSUED:** 05/15/98

**REVISED:** 04/01/05

**PREPARED BY:** David Rinn

**CITY STOCK NUMBER:**

**DESCRIPTION:** Pipes for ventilation of confined spaces, including manholes in floodplain areas when required. Construction to be of approved metallic pipe with acceptable corrosion-resistant coating inside and out. Vent outlet shall be covered with Type 304 stainless steel insect screen in frame to permit removal for cleaning. Vent diameter shall be as ordered: 3"-12".

<b>LISTING DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>	<b>APPROVAL</b>
07/01/98	FAST FABRICATORS, INC. (formerly B&R Pipe Fabrication) 800 Burlington Road Saginaw, TX 76179	Schedule 40 Black Steel Pipe and Fittings meeting ASTM A 53 and ASTM A 234, respectively. All surfaces coated with polyurethane (Futura brand).	D. Rinn

**NOTE:**