



**CITY OF AUSTIN  
QUALIFIED PRODUCTS LIST  
for  
POLYETHYLENE TUBING FOR LOW PRESSURE SEWERS**

**USING DEPARTMENT:** Water Utility    **ISSUED:** 04/01/11    **REVIEWED:** 04/01/12    **REVISED:** 04/01/12

**PREPARED BY:** Robert Lamb, P.E.    **CITY STOCK NUMBER:**

**DESCRIPTION:** Tubing, polyethylene, meeting ASTM D 2737, CTS-OD 1" thru 2", made of PE 4710, minimum Pressure Class 250 psi (SDR-9), solid green exterior and clear interior or solid green wall, contrasting-color heat-indented printline. Only compression fittings recommended by the manufacturer may be used and only with stainless steel insert stiffeners.

| <b>LISTING DATE</b> | <b>MANUFACTURER</b>  | <b>PRODUCT IDENTIFICATION/COMMENT</b> | <b>APPROVAL</b> |
|---------------------|--|---------------------------------------|-----------------|
| 01/01/11            | ENDOT INDUSTRIES, INC.<br>60 Green Pond Road<br>Rockaway, NJ 07866 | EndoPure                              | R. Lamb         |

**NOTE:**

1. Printline shall include all markings required by ASTM D 2737: nominal tubing size, type of PE plastic tubing material, pressure rating for water, ASTM designation D 2737, manufacturer's name or trademark and code, tubing test category. In addition, the printline shall include the date of manufacture that is recognizable as a date, and manufacturer's production code that includes resin source, manufacturing location, and extrusion line.
2. Tracer tape meeting SPL WW-597 to be installed 12 inches above top of tubing.