

DMR Copy of Record

Permit

Permit #: **TX0034207**
 Major:

Permittee: AUSTIN,CITY OF
 Permittee Address: 1700' SW INTX USHWY 183/FM 620
 AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP
 Facility Location: 1700' SW INTX USHWY 183 FM 620
 WILLIAMSON COUNTY
 AUSTIN, TX 78750

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 12/01/11 to 12/31/11**

DMR Due Date: **01/20/12**

Status: **NetDMR Validated**

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	6.8									19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	4 MO MIN								19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.1						=	6.9	12 - SU	0	15/30 - 15 Per Month	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM	12 - SU	02/DM - Twice Every Month	GR - GRAB				
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	13.2			26 - lb/d		=	7.2	=	11	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	124 DAILY AV			26 - lb/d	<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.5			26 - lb/d		=	0.3	=	0.5	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	25 DAILY AV			26 - lb/d	<=	3 DAILY AV	<=	7 DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.27	=	0.34	03 - Mgal/d							0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.99 DAILY AV			Req Mon DAILY MX	03 - Mgal/d							99/99 - Continuous	TM - TOTALZ
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample								=	0.07	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.							<=	.1 INST MAX	19 - mg/L	01/01 - Daily		GR - GRAB		
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample	=	1								19 - mg/L	0	01/01 - Daily	GR - GRAB	
						>=	1 MO MIN										01/01 - Daily	GR - GRAB	

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
					Permit Req.										19 - mg/L				
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	8.4			26 - lb/d		=	4.3	=	6.9	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d		<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2012-01-12 13:42 (Time Zone: -06:00)