

DMR Copy of Record

Permit

Permit #: **TX0034207**
 Major:

Permittee: AUSTIN,CITY OF
 Permittee Address: 1700' SW INTX USHWY 183/FM 620
 AUSTIN, TX 78750

Facility: ANDERSON MILL MUD WWTP
 Facility Location: 1700' SW INTX USHWY 183 FM 620
 WILLIAMSON COUNTY
 AUSTIN, TX 78750

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 11/01/11 to 11/30/11**

DMR Due Date: **12/20/11**

Status: **NetDMR Validated**

Considerations for Form Completion

P = 2-HOUR PEAK.11459-001

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type				
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	6.5				=	6.5					19 - mg/L	0	07/30 - 7 Times Every Month	GR - GRAB		
					Permit Req.	>=	4 MO MIN									19 - mg/L	01/07 - Weekly		GR - GRAB			
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample	=	6				=	6			=	6.9	12 - SU	0	13/30 - 13 Per Month	GR - GRAB		
					Permit Req.	>=	6 MINIMUM										9 MAXIMUM		12 - SU	02/DM - Twice Every Month	GR - GRAB	
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	5.8		26 - lb/d		=	2.6		=	3.2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS			
					Permit Req.	<=	124 DAILY AV		26 - lb/d		<=	15 DAILY AV		<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS			
					Value NODI																	
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	0.7		26 - lb/d		=	0.3		=	0.5	19 - mg/L	0	01/07 - Weekly	CP - COMPOS			
					Permit Req.	<=	25 DAILY AV		26 - lb/d		<=	3 DAILY AV		<=	7 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS			
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.23	=	0.33	03 - Mgal/d							0	99/99 - Continuous	TM - TOTALZ			
					Permit Req.	<=	.99 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								99/99 - Continuous	TM - TOTALZ			
					Value NODI																	
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample									=	0.08	19 - mg/L	0	01/01 - Daily	GR - GRAB			
					Permit Req.													<=	.1 INST MAX	19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI																	
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample	=	1				=	1				19 - mg/L	0	01/01 - Daily	GR - GRAB			
						>=	1 MO MIN												01/01 - Daily	GR - GRAB		

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
					Permit Req.											19 - mg/L				
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	6.5			26 - lb/d			<	2.9	=	4.6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	58 DAILY AV			26 - lb/d			<=	7 DAILY AV	<=	17 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-12-12 14:21 (Time Zone: -06:00)