

DMR Copy of Record

Permit

Permit #: **TX0097870**
Major: ☐

Permittee: AUSTIN, CITY OF
Permittee Address: 1.4M N DESSAU RD&YAGER LANE
AUSTIN, TX 78746

Facility: DESSAU WWTF
Facility Location: 1.4M N DESSAU RD AND YAGER LANE
AUSTIN, TX 78746

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 12/01/11 to 12/31/11**

DMR Due Date: **01/20/12**

Status: **NetDMR Validated**

Considerations for Form Completion

WQ0012971-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	9					19 - mg/L	0	17/30 - 17 Per Month	GR - GRAB
					Permit Req.						>=	5 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.8			=	7.5	12 - SU	0	01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		02/30 - Twice Per Month	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	12.2			26 - lb/d			=	9.9	=	11.6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	63 DAILY AV			26 - lb/d			<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.2			26 - lb/d			<	0.1	=	0.2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	13 DAILY AV			26 - lb/d			<=	3 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or	1 - Effluent Gross	0	--	Sample	=	0.15	=	0.2	03 - Mgal/d								0	99/99 - Continuous	TM - TOTALZ

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Permit Req.	<=	.5 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								0	99/99 - Continuous	TM - TOTALZ
					Value NODI															
					Sample						=	1.1			=	3.3	19 - mg/L			
					Permit Req.						>=	1 MO MIN			<=	4 MO MAX	19 - mg/L			
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample								<	1	=	1	30 - MPN/100mL	0	01/07 - Weekly	GR - GRAB
					Permit Req.								<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL			
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	4			26 - lb/d			=	3.2	=	3.6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	42 DAILY AV			26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L			
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E.coli: Results in MPN/100 mLs and NOT CFU/100 mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2012-01-12 13:45 (Time Zone: -06:00)