

## DMR Copy of Record

### Permit

Permit #: **TX0067466**  
 Major:

Permittee: AUSTIN, CITY OF  
 Permittee Address: 8250 CITATION AVE, 2400F E. FMR  
 AUSTIN, TX 787670000

Facility: THOROUGHbred FARMS WWTP  
 Facility Location: 8250 CITATION AVE, 2400F E. FMR 973  
 AUSTIN, TX 787670000

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: **From 12/01/11 to 12/31/11**

DMR Due Date: **01/20/12**

Status: **NetDMR Validated**

### Considerations for Form Completion

### Principal Executive Officer

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

### No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	6.4						19 - mg/L	0	06/30 - Six Per Month	GR - GRAB
					Permit Req.					>=	2 MO MIN					19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.2						<	2.2	=	2.9	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV					<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	7				=	8.1	12 - SU	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/30 - Monthly		GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.4						=	4.2	=	5.6	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV					<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.011	=	0.025	03 - Mgal/d								0	05/WK - Five Per Week	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV			03 - Mgal/d	Req Mon DAILY MX								05/WK - Five Per Week	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1				=	3.3	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week		GR - GRAB	
					Value NODI															

### Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

### Edit Check Errors

No errors.

**Comments**

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@ci.austin.tx.us  
Name: Jane Burazer  
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2012-01-12 13:50 (Time Zone: -06:00)