

## DMR Copy of Record

### Permit

Permit #: **TX0067466**

Major:

Permittee: AUSTIN, CITY OF  
 Permittee Address: 8250 CITATION AVE, 2400F E. FMR  
 AUSTIN, TX 787670000

Facility: THOROUGHbred FARMS WWTP  
 Facility Location: 8250 CITATION AVE, 2400F E. FMR 973  
 AUSTIN, TX 787670000

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: **From 10/01/11 to 10/31/11**

DMR Due Date: **11/20/11**

Status: **NetDMR Validated**

### Considerations for Form Completion

### Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

### No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	5					19 - mg/L	0	06/30 - Six Per Month	GR - GRAB
					Permit Req.					>=	2 MO MIN				19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI														
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	1.6					<	8.9	=	22.8	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV				<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.3			=	8	12 - SU	0	17/30 - 17 Per Month	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.2					=	8.2	=	21	19 - mg/L	0	05/30 - 5 Times Every Month	GR - GRAB
					Permit Req.	<=	11 DAILY AV				<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.018	=	0.027	03 - Mgal/d							0	05/WK - Five Per Week	IN - INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								05/WK - Five Per Week	IN - INSTAN
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.01			=	2.2	19 - mg/L	0	24/30 - 24 Per Month	GR - GRAB
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
					Value NODI														

### Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

### Edit Check Errors

No errors.

**Comments**

BOD: Lab Error reported for 10/18/11 sample due to the Blank outside QC Limits. BOD: As per TCEQ netDMR reporting requirements, the daily average consists of a minimum of four measurements. When four samples are not available in a calendar month, the arithmetic average of the four most recent measurements shall be used as the daily avg. Therefore, the 9/29/11 BOD result (22.8 mg/L) was averaged with the October measurements.

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@ci.austin.tx.us  
Name: Jane Burazer  
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-11-14 17:07 (Time Zone: -06:00)