

DMR Copy of Record

Permit

Permit #: **TX0046981**
 Major:

Permittee: AUSTIN, CITY OF (WALNUT CREEK)
 Permittee Address: 7113 EAST FM 969
 AUSTIN, TX 787678859

Facility: CITY OF AUSTIN(WALNUT CREEK)
 Facility Location: 7113 EAST FM 969
 TRAVIS COUNTY
 AUSTIN, TX 787678859

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period: **From 12/01/11 to 12/31/11**

DMR Due Date: **01/20/12**

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type								
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units							
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	7.2				=	7.2					19 - mg/L	0	01/01 - Daily	GR - GRAB						
					Permit Req.	>=	6 MO MIN										19 - mg/L	0	01/01 - Daily	GR - GRAB						
					Value NODI																					
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.5				=	6.5		=	7.4		12 - SU	0	01/01 - Daily	GR - GRAB						
					Permit Req.	>=	6 MINIMUM												12 - SU	0	01/01 - Daily	GR - GRAB				
					Value NODI																					
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2149			26 - lb/d	=	4.5		=	9.7		19 - mg/L	0	01/01 - Daily	CP - COMPOS						
					Permit Req.	<=	9383 DAILY AV			26 - lb/d											19 - mg/L	0	01/01 - Daily	CP - COMPOS		
					Value NODI																					
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	181			26 - lb/d	<	0.4		=	1.6		19 - mg/L	0	01/01 - Daily	CP - COMPOS						
					Permit Req.	<=	1251 DAILY AV			26 - lb/d													19 - mg/L	0	01/01 - Daily	CP - COMPOS
					Value NODI																					
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	57	=	70.1	03 - Mgal/d								0	99/99 - Continuous	TM - TOTALZ						
					Permit Req.		Req Mon DAILY AV			Req Mon DAILY MX	03 - Mgal/d											99/99 - Continuous	TM - TOTALZ			

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
					Value NODI														
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample	=		74056	78 - gal/min							0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=		114583 2HR PEAK	78 - gal/min								99/99 - Continuous	TM - TOTALZ	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	47.8		03 - Mgal/d							0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	75 ANNL AVG		03 - Mgal/d								99/99 - Continuous	TM - TOTALZ	
					Value NODI														
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0	19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.							<	.1 INST MAX	19 - mg/L			01/01 - Daily	GR - GRAB	
					Value NODI														
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1			19 - mg/L		0	01/01 - Daily	GR - GRAB	
					Permit Req.	>=					1 MINIMUM			19 - mg/L			01/01 - Daily	GR - GRAB	
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	7	=	44	30 - MPN/100mL	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.								Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL		05/WK - Five Per Week	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	962		26 - lb/d			<	2	=	2.5	19 - mg/L		01/01 - Daily	CP - COMPOS
					Permit Req.	<=	6255 DAILY AV		26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
						<input checked="" type="checkbox"/>

Comments

E. Coli: Units reported in MPN/100ml, not CFU/100ml

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@ci.austin.tx.us

Date/Time: 2012-01-12 13:57 (Time Zone: -06:00)

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us