

DMR Copy of Record

Permit

Permit #: **TX0046981**
 Major:

Permittee: AUSTIN, CITY OF (WALNUT CREEK)
 Permittee Address: 7113 EAST FM 969
 AUSTIN, TX 787678859

Facility: CITY OF AUSTIN(WALNUT CREEK)
 Facility Location: 7113 EAST FM 969
 TRAVIS COUNTY
 AUSTIN, TX 787678859

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY-OUTFALL 001

Report Dates & Status

Monitoring Period: **From 10/01/11 to 10/31/11**

DMR Due Date: **11/20/11**

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	6.4						19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	6 MO MIN							19 - mg/L	0	01/01 - Daily	GR - GRAB
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.2		=	7.2		12 - SU	0	01/01 - Daily	GR - GRAB		
					Permit Req.					>=	6 MINIMUM		<=	9 MAXIMUM		12 - SU	0	01/01 - Daily	GR - GRAB		
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	470		26 - lb/d			<	1.2	=	3.4	19 - mg/L	0	01/01 - Daily	CP - COMPOS		
					Permit Req.	<=	9383 DAILY AV		26 - lb/d		<=	15 DAILY AV	<=	40 DAILY MX	19 - mg/L	0	01/01 - Daily	CP - COMPOS			
					Value NODI																
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	157		26 - lb/d			<	0.4	=	1.5	19 - mg/L	0	01/01 - Daily	CP - COMPOS		
					Permit Req.	<=	1251 DAILY AV		26 - lb/d		<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L	0	01/01 - Daily	CP - COMPOS			
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	48	=	60	03 - Mgal/d							0	99/99 - Continuous	TM - TOTALZ		
					Permit Req.		Req Mon DAILY AV		Req Mon DAILY MX	03 - Mgal/d										0	99/99 - Continuous

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	P - See Comments	0	--	Sample	=		51605	78 - gal/min								99/99 - Continuous	TM - TOTALZ		
					Permit Req.		<=		114583 2HR PEAK	78 - gal/min								99/99 - Continuous	TM - TOTALZ	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	Y - Effluent Gross (Supplementary)	0	--	Sample	=	46.7		03 - Mgal/d								99/99 - Continuous	TM - TOTALZ		
					Permit Req.	<=	75 ANNL AVG		03 - Mgal/d									99/99 - Continuous	TM - TOTALZ	
					Value NODI															
50060	Chlorine, total residual	A - Disinfection, Process Complete	0	--	Sample							=	0	19 - mg/L			01/01 - Daily	GR - GRAB		
					Permit Req.							<	.1 INST MAX	19 - mg/L				01/01 - Daily	GR - GRAB	
					Value NODI															
50060	Chlorine, total residual	B - Prior to Disinfection	0	--	Sample					=	1			19 - mg/L			01/01 - Daily	GR - GRAB		
					Permit Req.						>=	1 MINIMUM			19 - mg/L			01/01 - Daily	GR - GRAB	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample							<	17	=	866	3Z - CFU/100mL		05/WK - Five Per Week	GR - GRAB	
					Permit Req.									Req Mon DAILY AV		Req Mon DAILY MX	3Z - CFU/100mL		05/WK - Five Per Week	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	1305		26 - lb/d			<	3.3	=	6.6	19 - mg/L		01/01 - Daily	CP - COMPOS	
					Permit Req.	<=	6255 DAILY AV		26 - lb/d			<=	10 DAILY AV	<=	25 DAILY MX	19 - mg/L		01/01 - Daily	CP - COMPOS	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

E.coli: Results in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF (WALNUT CREEK)

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-12-21 13:50 (Time Zone: -06:00)