

Permit

Major:

Permittee Address: 4800' E INTX BLUE BLUFF RD &
AUSTIN, TX 78767

Facility Location: 4800' E INTX BLUE BLUFF RD &
LINDEL LN, TRAVIS COUNTY
AUSTIN, TX 78767

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

Status: NetDMR Validated

Principal Executive Officer

Telephone: 512-972-0101

No Data Indicator (NODI)

Parameter	Monitor
-----------	---------

[illegible]

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample	<	0.16			26 - lb/d			<	0.11	=	0.2	19 - mg/L	0	01/07 - Weekly	CP - COMPO
					Permit Req.	<=	6.3 DAILY AV			26 - lb/d			<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPO
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.17	=	0.29	03 - Mgal/d							0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								99/99 - Continuous	TM - TOTALZ	
					Value NODI															
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	1	=	3	30 - MPN/100mL	0	01/01 - Daily	GR - GRAB	
					Permit Req.							<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL		01/01 - Daily	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	3.1			26 - lb/d			<	2	<	2	19 - mg/L	0	01/07 - Weekly	CP - COMPO
					Permit Req.	<=	31 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPO
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E.coli results in MPN/100mLs NOT CFU/100mLs cBOD: 11/1/11 Lab Error due to GGA standard outside QC limits.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2011-12-12 14:29 (Time Zone: -06:00)