

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B	WQ0010543-011	1	1 1 0 7	15650
SYS	PERMIT NUMBER	SET	YEAR MO.	EID

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**
 SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	PERMITTED		VALUE	UNITS		
316164024 FEC. COLI DLY AVG	REPORTED	PERMITTED					
			<2	#/100 ML	0 11	2/WEEK	03 GRABPKLOAD
			20:000		11	2/WEEK	03 GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	PERMITTED					
			2	#/100 ML	0 11	2/WEEK	03 GRABPKLOAD
			75:000		11	2/WEEK	03 GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	PERMITTED					
			0.85	MGD	0 02	CONT	11 CONT
					02	CONT	11 CONT
800821024 BOD CARB DLY AVG	REPORTED	PERMITTED					
			<2.0	MG/L	0 11	2/WEEK	03 GRABPKLOAD
			5:000		11	2/WEEK	03 GRABPKLOAD
820796624 TURBIDITY 30DAYAVG	REPORTED	PERMITTED					
			2.25	NTU	0 11	2/WEEK	03 GRABPKLOAD
			3:000		11	2/WEEK	03 GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	PERMITTED					
			WW0018247	NUMBER	0 01		NA NA
					01	01	NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	PERMITTED					
			12/11/12	DATE	0 01		NA NA
					01	01	NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	PERMITTED					
			A	LETTER	0 01		NA NA
					01	01	NA NA
	REPORTED	PERMITTED					
	REPORTED	PERMITTED					

COMMENTS AND EXPLANATIONS (Reference all attachments here)
 Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.
 Walnut Creek WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Mike Welch		1 1 0 8 0 8
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 1 0 8 0 8
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY

RECEIVED

AUG 19 2011


ENFORCEMENT DIVISION

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865

Page 2 of 3



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	1 1 YEAR	0 7 MO.	15651 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS **TCEQ COPY**

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE		
	REPORTED	VALUE		UNITS	NO.	PERIOD	TYPE	TYPE
000085342 TRANSFER DAYS MON	REPORTED	31	DAY	0	01		01	
	PERMITTED				01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	<3	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	200.000			14	1/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	20	#/100 ML	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	800.000			14	1/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	3.77	MGD	0	02	CONT	11	CONT
	PERMITTED				14	1/WEEK	02	GRAB
800821024 BOD CARB DLY AVG	REPORTED	<2.0	MG/L	0	11	2/WEEK	03	GRABPKLOAD
	PERMITTED	15.000			14	1/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	NUMBER	0	01			NA
	PERMITTED				01	01		NA NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	DATE	0	01			NA
	PERMITTED				01	01		NA NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	LETTER	0	01			NA
	PERMITTED				01	01		NA NA
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							
	REPORTED							
	PERMITTED							

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012,
EPA ID TX0071889. South Austin Regional WWTP transferred reclaimed water for 31 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE	NAME	SIGNATURE	DATE
	Randall Swenson	<i>Randall Swenson</i>	1 1 0 8 0 8
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		1 1 0 8 0 8
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

RECEIVED
AUG 19 2011
ENFORCEMENT DIVISION

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	1 1 YEAR	0 7 MO.	15652 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
	REPORTED	VALUE		UNITS			
500507124 FLOW	REPORTED	4.62	MGD	0	01		01
DAILY AVG	PERMITTED				01	NA	01
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	NUMBER	0	01		NA
EXPIRATION OF OPERATOR CERTIFICATE	PERMITTED				01	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	LETTER	0	01		NA
	PERMITTED				01	01	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)
Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 31 days and South Austin Regional WWTP transferred reclaimed water 31 days.

<small>I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE</small>	NAME Mike Welch	SIGNATURE 	DATE 1 1 0 8 0 8
TELEPHONE NUMBER 5 1 2 9 7 2 0 1 0 1	PLANT OPERATOR Greg Meszaros, Director	PLANT OPERATOR	YEAR MO. DAY 1 1 0 8 0 8
NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER	YEAR MO. DAY

RECEIVED

AUG 19 2011

ENFORCEMENT DIVISION