

DMR Copy of Record

Permit

Permit #: **TX0097870**
 Major:

Permittee: AUSTIN, CITY OF
 Permittee Address: 1.4M N DESSAU RD&YAGER LANE AUSTIN, TX 78746

Facility: DESSAU WWTF
 Facility Location: 1.4M N DESSAU RD AND YAGER LANE AUSTIN, TX 78746

Permitted Feature: 001
 External Outfall

Discharge: **001-A**
 DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: **From 01/01/11 to 01/31/11**

DMR Due Date: **02/20/11**

Status: **NetDMR Validated**

Considerations for Form Completion

WQ0012971-001

Principal Executive Officer

First Name: Greg
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	S		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	5.5									19 - mg/L	27/30 - 27 Per Month	G	
					Permit Req.	>=	5 MO MIN										19 - mg/L	01/07 - Weekly	G
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.7					=	8.2		12 - SU	01/01 - Daily	G		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM		12 - SU	02/30 - Twice Per Month	G			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	11.6			26 - lb/d	=	10.1	=	18.2		19 - mg/L	01/07 - Weekly	CI	
					Permit Req.	<=	63 DAILY AV			26 - lb/d	<=	15 DAILY AV	<=	40 DAILY MX		19 - mg/L	01/07 - Weekly	CI	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.1			26 - lb/d	<	0.1	=	0.1		19 - mg/L	01/07 - Weekly	CI	
					Permit Req.	<=	13 DAILY AV			26 - lb/d	<=	3 DAILY AV	<=	10 DAILY MX		19 - mg/L	01/07 - Weekly	CI	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.13	=	0.15	03 - Mgal/d							99/99 - Continuous	TT	
					Permit Req.	<=	.5 DAILY AV			Req Mon DAILY MX	03 - Mgal/d							99/99 - Continuous	TT
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample	=	1.1					=	2.2		19 - mg/L	01/01 - Daily	G		
					Permit Req.	>=	1 MO MIN				<=	4 MO MAX		19 - mg/L	01/01 - Daily	G			
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample	<	2				<	2	=	6		30 - MPN/100mL	01/07 - Weekly	G	
					Permit Req.	<=	120 DAILY AV				<=	374 DAILY MX	<=	32 - CFU/100mL		01/07 - Weekly	G		
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	5.9			26 - lb/d	=	5.2	=	7		19 - mg/L	01/07 - Weekly	CI	
					Permit Req.	<=	42 DAILY AV			26 - lb/d	<=	10 DAILY AV	<=	25 DAILY MX		19 - mg/L	01/07 - Weekly	CI	
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and S Type.

Edit Check Errors

Parameter Code	Parameter Name	Monitoring Location	Field	Type	Description	Know
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E.coli results in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-02-14 09:38 (Time Zone: -06:00)