

## DMR Copy of Record

### Permit

Permit #: **TX0101532**  
 Major:

Permittee: AUSTIN, CITY OF  
 Permittee Address: 0.25MI W OF INTX GILES RD & AUSTIN, TX 78701

Facility: HARRIS BRANCH WWTP  
 Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701

Permitted Feature: 001  
 External Outfall

Discharge: **001-A**  
 DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: From 02/01/11 to 02/28/11

DMR Due Date: 03/20/11

Status: **NetDMR Validated**

### Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

### Principal Executive Officer

First Name: Greg  
 Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

### No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type				
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	5.5						19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.						>=	5 MO MIN								19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample						=	6			=	7.2	12 - SU	0	26/30 - 26 Per Month	GR - GRAB		
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB		
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3.7			26 - lb/d			=	2.1	=	4.4	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB		
					Permit Req.	<=	17 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB		
					Value NODI																	
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	3.6			26 - lb/d			<	2	=	8.8	19 - mg/L	0	11/30 - 11 Per Month	GR - GRAB		
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB		
					Value NODI																	
00665	Phosphorus,	1 - Effluent	0	--	Sample	=	1.4			26 - lb/d			=	0.79	=	1.37	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB		
					Permit		3.3			26 -				1		6			01/07 -	GR -		

	total (as P)	Gross				Req.	<=	DAILY AV		lb/d		<=	DAILY AV	<=	SINGGRAB	19 - mg/L		Weekly	GRAB	
						Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--		Sample	=	0.22	=	0.3	03 - Mgal/d						0	01/01 - Daily	IN - INSTAN	
						Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN	
						Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--		Sample				=	1		=	3.1		19 - mg/L		26/30 - 26 Per Month	GR - GRAB	
						Permit Req.				>=	1 MO MIN		<=	4 MO MAX		19 - mg/L		05/WK - Five Per Week	GR - GRAB	
						Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--		Sample				<	3	=	75		30 - MPN/100mL			02/07 - Twice Every Week	GR - GRAB	
						Permit Req.	<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL						0	01/30 - Monthly	GR - GRAB	
						Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--		Sample	<	5			26 - lb/d	<	2.9	=	5.6		19 - mg/L		02/07 - Twice Every Week	
						Permit Req.	<=	17 DAILY AV			26 - lb/d	<=	5 DAILY AV	<=	30 SINGGRAB		19 - mg/L	0	01/07 - Weekly	GR - GRAB
						Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E.coli results in MPN/100mLs and NOT CFU/100mLs.

**Attachments**

No attachments.

**Report Last Saved By**

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-03-14 11:49 (Time Zone: -05:00)

