

DMR Copy of Record

Permit

Permit #: **TX0101532**
 Major:

Permittee: **AUSTIN, CITY OF**
 Permittee Address: **0.25MI W OF INTX GILES RD & AUSTIN, TX 78701**

Facility: **HARRIS BRANCH WWTP**
 Facility Location: **0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701**

Permitted Feature: **001 External Outfall**

Discharge: **001-A DOMESTIC FACILITY - 001**

Report Dates & Status

Monitoring Period: **From 06/01/11 to 06/30/11**

DMR Due Date: **07/20/11**

Status: **NetDMR Validated**

Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

Principal Executive Officer

First Name: **Greg**
 Last Name: **Meszaros**

Title: **Director**

Telephone: **512-972-0101**

No Data Indicator (NODI)

Form NODI: **--**

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units		
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	5					19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.						>=	5 MO MIN							19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample						=	6		=	7.3	12 - SU	0	07/30 - 7 Times Every Month	GR - GRAB		
					Permit Req.						>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB		
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	3.6			26 - lb/d		<	1.4	=	4.7	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB		
					Permit Req.	<=	17 DAILY AV			26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB		
					Value NODI																
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.3			26 - lb/d		<	0.1	=	0.2	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB		
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d		<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB		
					Value NODI																
					Sample	=	1.38			26 - lb/d		=	0.55	=	1.14	19 - mg/L		02/07 - Twice Every Week	GR - GRAB		

00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Permit Req.	<=	3.3 DAILY AV		26 - lb/d		<=	1 DAILY AV	<=	6 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB			
					Value NODI																
					Sample	=	0.29	=	0.43	03 - Mgal/d											01/01 - Daily
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - Mgal/d						0	05/WK - Five Per Week	IN - INSTAN			
					Value NODI																
					Sample					=	1.1			=	3.9	19 - mg/L				01/01 - Daily	GR - GRAB
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB			
					Value NODI																
					Sample																01/01 - Daily
X 51040	E. coli	1 - Effluent Gross	0	--	Permit Req.						<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL	0	01/30 - Monthly	GR - GRAB			
					Value NODI																
					Sample																02/30 - Twice Per Month
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Permit Req.	<=	17 DAILY AV		26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB			
					Value NODI																
					Sample	<	5.1			26 - lb/d			<	2.1	=	2.2	19 - mg/L				02/07 - Twice Every Week

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter Code	Name	Monitoring Location	Field	Type	Description	Acknowledge
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E.coli in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
 Name: Jane Burazer
 E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2011-07-12 12:17 (Time Zone: -05:00)