

DMR Copy of Record

Permit

Permit #: TX0101532

Major: ☒

Permitted Feature: 001
External Outfall

Permittee: AUSTIN, CITY OF
Permittee Address: 0.25MI W OF INTX GILES RD &
AUSTIN, TX 78701

Facility: HARRIS BRANCH WWTP
Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN
AUSTIN, TX 78701

Discharge: 001-A
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 03/01/11 to 03/31/11

DMR Due Date: 04/20/11

Status: NetDMR Validated

Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	5.3					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	5 MO MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6			=	7.3	12 - SU	0	19/30 - 19 Per Month	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	6.2			26 - lb/d			=	2.8	=	5.9	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d			<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	=	1.2			26 - lb/d			=	0.5	=	1.5	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d			<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
					Sample	=	2.27			26 - lb/d			=	0.97	=	1.5	19 - mg/L		02/07 - Twice Every Week	GR - GRAB

00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Permit Req.	<=	3.3 DAILY AV		26 - lb/d		<=	1 DAILY AV	<=	6 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.27	=	0.49	03 - Mgal/d						0	01/01 - Daily	IN - INSTAN
					Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1		=	3.4	19 - mg/L	0	29/30 - 29 Per Month	GR - GRAB
					Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Value NODI													
X 51040	E. coli	1 - Effluent Gross	0	--	Sample						<	33	=	2827	30 - MPN/100mL	2	11/30 - 11 Per Month	GR - GRAB
					Permit Req.						<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL	2	01/30 - Monthly	GR - GRAB
					Value NODI													
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	5.6		26 - lb/d		<	2.6	=	3.9	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB
					Permit Req.	<=	17 DAILY AV		26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E.coli results in MPN/100mLs and NOT CFU/100mLs. E.coli: 2 excursions for the month. The 3/11/11 and 3/12/11 sample results exceeded the Daily Max permit limit.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2011-04-12 13:43 (Time Zone: -05:00)

