

## DMR Copy of Record

### Permit

Permit #: **TX0101532**

Major:

Permitted Feature: 001  
External Outfall

Permittee: AUSTIN, CITY OF  
Permittee Address: 0.25MI W OF INTX GILES RD & AUSTIN, TX 78701

Facility: HARRIS BRANCH WWTP  
Facility Location: 0.25MI W OF INTX GILES RD BOYCE LN AUSTIN, TX 78701

Discharge: **001-A**  
DOMESTIC FACILITY - 001

### Report Dates & Status

Monitoring Period: **From 05/01/11 to 05/31/11**

DMR Due Date: **06/20/11**

Status: **NetDMR Validated**

### Considerations for Form Completion

INTERIM I PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.80 MGD FACILITIES.

### Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

### No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type	
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	5									19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	5 MO MIN									19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6					=	6.6		12 - SU	0	14/30 - 14 Per Month	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM		12 - SU	01/30 - Monthly		GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2.7			26 - lb/d		=	1.4	=	3.2	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB
					Permit Req.	<=	17 DAILY AV			26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.3			26 - lb/d		<	0.2	=	0.4	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB
					Permit Req.	<=	6.7 DAILY AV			26 - lb/d		<=	2 DAILY AV	<=	15 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
					Sample	=	1.17			26 - lb/d		=	0.61	=	1.36	19 - mg/L		02/07 - Twice Every Week	GR - GRAB

00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Permit Req.	<=	3.3 DAILY AV		26 - lb/d		<=	1 DAILY AV	<=	6 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.24	=	0.33	03 - Mgal/d						0	01/01 - Daily	IN - INSTAN	
					Permit Req.	<=	.4 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								05/WK - Five Per Week	IN - INSTAN
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1.1		=	3.8	19 - mg/L	0	26/30 - 26 Per Month	GR - GRAB	
					Permit Req.					>=	1 MO MIN		<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB	
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample						<	6	=	111	30 - MPN/100mL	0	02/07 - Twice Every Week	GR - GRAB	
					Permit Req.						<=	120 DAILY AV	<=	374 SINGGRAB	3Z - CFU/100mL	0	01/30 - Monthly	GR - GRAB	
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	4.1		26 - lb/d		<	2.1	=	3.1	19 - mg/L	0	02/07 - Twice Every Week	GR - GRAB	
					Permit Req.	<=	17 DAILY AV		26 - lb/d		<=	5 DAILY AV	<=	30 SINGGRAB	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E.coli results in MPN/100mLs and NOT CFU/100mLs

**Attachments**

No attachments.

**Report Last Saved By**

**AUSTIN, CITY OF**

User: jane.burazer@ci.austin.tx.us  
 Name: Jane Burazer  
 E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-06-13 08:29 (Time Zone: -05:00)

