

DMR Copy of Record

Permit

Permit #: **TX0067466**

Major:

Permitted Feature: 001
External Outfall

Permittee: AUSTIN, CITY OF
Permittee Address: 8250 CITATION AVE, 2400F E. FMR
AUSTIN, TX 787670000

Facility: THOROUGHbred FARMS WWTP
Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
AUSTIN, TX 787670000

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 04/01/11 to 04/30/11

DMR Due Date: 05/20/11

Status: **NetDMR Validated**

Considerations for Form Completion

14459-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	7				19 - mg/L	0	06/30 - Six Per Month	GR - GRAB	
					Permit Req.						>=	2 MO MIN						19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.2			26 - lb/d			<	2	<	2	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.3			=	8	12 - SU	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.2			26 - lb/d			=	2.3	=	3.4	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	11 DAILY AV			26 - lb/d			<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
										03 -								05/WK -	IN -	

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.012	=	0.018	Mgal/d										Five Per Week	INSTAN			
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d												0	05/WK - Five Per Week	IN - INSTAN
					Value NODI																			
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1			=	1.98	19 - mg/L				05/WK - Five Per Week	GR - GRAB			
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L					0	05/WK - Five Per Week	GR - GRAB	
					Value NODI																			

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-05-13 10:58 (Time Zone: -05:00)