

DMR Copy of Record

Permit

Permit #: **TX0067466**
Major: ☐

Permittee: AUSTIN, CITY OF
Permittee Address: 8250 CITATION AVE, 2400F E. FMR
AUSTIN, TX 787670000
Discharge: **001-A**
DOMESTIC FACILITY - 001

Facility: THOROUGHbred FARMS WWTP
Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
AUSTIN, TX 787670000

Permitted Feature: 001
External Outfall

Report Dates & Status

Monitoring Period: From 01/01/11 to 01/31/11

DMR Due Date: 02/20/11

Status: NetDMR Validated

Considerations for Form Completion

14459-001

Principal Executive Officer

First Name: Greg
Last Name: Meszaros

Title: Director

Telephone: 512-972-0101

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample						=	7.6					19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	2 MO MIN					19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	<	0.4		26 - lb/d		<	2	<	2		19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	11 DAILY AV		26 - lb/d		<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB		
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.8			=	7.8	12 - SU	19/30 - 19 Per Month	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.7		26 - lb/d		=	3	=	4.9		19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	11 DAILY AV		26 - lb/d		<=	20 DAILY AV	<=	65 SINGGRAB	19 - mg/L	01/07 - Weekly	GR - GRAB		
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.022	=	0.034	03 - Mgal/d							01/01 - Daily	IN - INSTAN	
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							05/WK - Five Per Week	IN - INSTAN	
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1			=	2.2	19 - mg/L	05/WK - Five Per Week	GR - GRAB	
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	05/WK - Five Per Week	GR - GRAB	
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-02-14 09:44 (Time Zone: -06:00)