

Permit

Permit #: TX0067466

Major:

Permittee: AUSTIN, CITY OF

Permittee Address: 8250 CITATION AVE, 2400F E. FMR
AUSTIN, TX 787670000

Facility: THOROUGHBRED FARMS WWTP

Facility Location: 8250 CITATION AVE, 2400F E. FMR 973
AUSTIN, TX 787670000

Permitted Feature: 001
External Outfall

Discharge: **001-A**
DOMESTIC FACILITY - 001

Report Dates & Status

Monitoring Period: From 06/01/11 to 06/30/11

DMR Due Date: 07/20/11

Status: NetDMR Validated

Considerations for Form Completion

14459-001

Principal Executive Officer

First Name: Greg

Title: Director

Telephone: 512-972-0101

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

[illegible]

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.019	=	0.029	Mgal/d								Five Per Week	INSTAN
					Permit Req.	<=	.065 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							0	05/WK - Five Per Week	IN - INSTAN
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	1			=	1.98	19 - mg/L	05/WK - Five Per Week	GR - GRAB	
					Permit Req.					>=	1 MO MIN			<=	4 MO MAX	19 - mg/L	0	05/WK - Five Per Week	GR - GRAB
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-07-12 12:19 (Time Zone: -05:00)