

Permit

Major:

Permittee:	AUSTIN, CITY OF
Permittee Address:	4800' E INTX BLUE BLUFF RD & AUSTIN, TX 78767

Facility:	WILD HORSE RANCH WWTP
Facility Location:	4800' E INTX BLUE BLUFF RD & LINDEL LN, TRAVIS COUNTY AUSTIN, TX 78767

Discharge:	001-A DOMESTIC FACILITY - 001
-------------------	---

DMR Due Date: 05/20/11

Considerations for Form Completion

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

First Name: Greg

Title:	Director
---------------	----------

Telephone:

Last Name: Meszaros

No Data Indicator (NODI)

Form NODI: --

[illegible]

00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Permit Req.	<=	6.3 DAILY AV		26 - lb/d		<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.17	=	0.21	03 - Mgal/d						0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - Mgal/d							99/99 - Continuous	TM - TOTALZ
					Value NODI													
X 51040	E. coli	1 - Effluent Gross	0	--	Sample						<	2	=	117	30 - MPN/100mL	0	01/01 - Daily	GR - GRAB
					Permit Req.	<=					<=	120 DAILY AV	<=	374 DAILY MX	32 - CFU/100mL		01/01 - Daily	GR - GRAB
					Value NODI													
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	2.9		26 - lb/d		<	2	<	2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV		26 - lb/d		<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	☒

Comments

E.coli results in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-05-13 11:10 (Time Zone: -05:00)