

DMR Copy of Record

Permit

Permit #: TX0124800	Permittee: AUSTIN, CITY OF	Facility: WILD HORSE RANCH WWTP
Major: <input type="checkbox"/>	Permittee Address: 4800' E INTX BLUE BLUFF RD & AUSTIN, TX 78767	Facility Location: 4800' E INTX BLUE BLUFF RD & LINDEL LN, TRAVIS COUNTY AUSTIN, TX 78767
Permitted Feature: 001 External Outfall	Discharge: 001-A DOMESTIC FACILITY - 001	

Report Dates & Status

Monitoring Period: From 01/01/11 to 01/31/11	DMR Due Date: 02/20/11	Status: NetDMR Validated
---	-------------------------------	---------------------------------

Considerations for Form Completion

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

Principal Executive Officer

First Name: Greg	Title: Director	Telephone: 512-972-0101
Last Name: Meszaros		

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	S		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample					=	7.9					19 - mg/L	0	08/30 - Eight Every Month	G
					Permit Req.					>=	5 MO MIN					19 - mg/L		01/07 - Weekly	G
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.7		=	7.8	12 - SU	0	11/30 - 11 Per Month	G	
					Permit Req.					>=	6 MINIMUM		<=	9 MAXIMUM	12 - SU		02/30 - Twice Per Month	G	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.7					=	0.9	=	1.3	19 - mg/L	0	01/07 - Weekly	CI
					Permit Req.	<=	31 DAILY AV					<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CI
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.2					<	0.1	<	0.1	19 - mg/L	0	01/07 - Weekly	CI
					Permit Req.	<=	13 DAILY AV					<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/07 - Weekly	CI
					Value NODI														
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample	=	0.14					=	0.08	=	0.09	19 - mg/L	0	01/07 - Weekly	CI
					Permit Req.	<=	6.3 DAILY AV					<=	1 DAILY AV	<=	4 DAILY MX	19 - mg/L		01/07 - Weekly	CI
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.21	=	0.37	03 - Mgal/d							0	99/99 - Continuous	TI
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - Mgal/d								99/99 - Continuous	TI
					Value NODI														
X 51040	E. coli	1 - Effluent Gross	0	--	Sample							<	1	=	2	30 - MPN/100mL	0	01/01 - Daily	G
					Permit Req.							<=	120 DAILY AV	<=	374 DAILY MX	32 - CFU/100mL		01/01 - Daily	G
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	3.6					<	2	<	2	19 - mg/L	0	01/07 - Weekly	CI
					Permit Req.	<=	31 DAILY AV					<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CI
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and S Type.

Edit Check Errors

Parameter Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknow
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

Comments

E.coli results in MPN/100mLs and NOT CFU/100mLs.

Attachments

No attachments.

Report Last Saved By

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us
Name: Jane Burazer
E-Mail: jane.burazer@ci.austin.tx.us

Date/Time: 2011-02-14 09:46 (Time Zone: -06:00)