

**DMR Copy of Record**

**Permit**

Permit #: **TX0124800**  
 Major:

Permittee: **AUSTIN, CITY OF**  
 Permittee Address: **4800' E INTX BLUE BLUFF RD & AUSTIN, TX 78767**

Facility: **WILD HORSE RANCH WWTP**  
 Facility Location: **4800' E INTX BLUE BLUFF RD & LINDEL LN, TRAVIS COUNTY AUSTIN, TX 78767**

Permitted Feature: **001 External Outfall**

Discharge: **001-A DOMESTIC FACILITY - 001**

**Report Dates & Status**

Monitoring Period: **From 03/01/11 to 03/31/11**

DMR Due Date: **04/20/11**

Status: **NetDMR Validated**

**Considerations for Form Completion**

INTERIM PHASE EFFECTIVE UPON ISSUANCE AND LASTING UNTIL THE COMPLETION OF THE 0.99 MGD FACILITIES.

**Principal Executive Officer**

First Name: **Greg**  
 Last Name: **Meszaros**

Title: **Director**

Telephone: **512-972-0101**

**No Data Indicator (NODI)**

Form NODI: **--**

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	7.6								19 - mg/L	0	14/30 - 14 Per Month	GR - GRAB	
					Permit Req.	>=	5 MO MIN										19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.9					=	7.8	12 - SU	0	11/30 - 11 Per Month	GR - GRAB		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM	12 - SU	02/30 - Twice Per Month		GR - GRAB			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.4		26 - lb/d		=	0.9	=	1.5	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	31 DAILY AV		26 - lb/d		<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	0	--	Sample	<	0.2		26 - lb/d		<	0.1	<	0.1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	13 DAILY AV		26 - lb/d		<=	2 DAILY AV	<=	10 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI														
	Phosphorus,	1 - Effluent			Sample	=	0.24		26 - lb/d		=	0.17	=	0.19	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Permit		6.3		26 -			1		4 DAILY			01/07 -	CP -	

00665	total (as P)	Gross	0	--	Req.	<=	DAILY AV		lb/d		<=	DAILY AV	<=	MX	19 - mg/L	0	Weekly	COMPOS
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.17	=	0.22	03 - Mgal/d						0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	.75 DAILY AV		Req Mon DAILY MX	03 - Mgal/d						0	99/99 - Continuous	TM - TOTALZ
					Value NODI													
X 51040	E. coli	1 - Effluent Gross	0	--	Sample						<	1	=	18	30 - MPN/100mL	0	01/01 - Daily	GR - GRAB
					Permit Req.	<=	120 DAILY AV	<=	374 DAILY MX	3Z - CFU/100mL						0	01/01 - Daily	GR - GRAB
					Value NODI													
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	<	3.2			26 - lb/d	<	2.2	=	3.1	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	31 DAILY AV			26 - lb/d	<=	5 DAILY AV	<=	20 DAILY MX	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Units	Soft	The selected units do not match the units specified by the permit for this parameter. The provided sample value(s) may be outside the permit limit. (Error Code: 3)	<input checked="" type="checkbox"/>

**Comments**

E.coli results in MPN/100mLs and NOT CFU/100mLs.

**Attachments**

No attachments.

**Report Last Saved By**

AUSTIN, CITY OF

User: jane.burazer@ci.austin.tx.us

Name: Jane Burazer

E-Mail: jane.burazer@ci.austin.tx.us

Date/Time:

2011-04-13 16:33 (Time Zone: -05:00)