

Drinking Water Quality Report  
Date Range: 01-DEC-2018 to 31-DEC-2018

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.5	AVG	9.6
			MAX	9.9	MAX	9.6	MAX	9.7
			MIN	9.4	MIN	9.4	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	57	AVG	58	AVG	55
			MAX	68	MAX	63	MAX	63
			MIN	53	MIN	53	MIN	50
Total Hardness	MG/L	SM 2340 C	AVG	80	AVG	84	AVG	77
			MAX	89	MAX	88	MAX	82
			MIN	76	MIN	79	MIN	74
Total Solids	MG/L	SM 2540 B	AVG	140	AVG	146	AVG	158
			MAX	162	MAX	164	MAX	174
			MIN	116	MIN	132	MIN	130
Chloramines	MG/L	SM 4500-CL F	AVG	2.93	AVG	2.80	AVG	2.84
			MAX	3.05	MAX	3.05	MAX	3.05
			MIN	2.75	MIN	2.15	MIN	2.75
Sulfate	MG/L	SM 4500-SO4 E	AVG	20.2	AVG	7.6	AVG	37.1
			MAX	20.2	MAX	7.6	MAX	37.1
			MIN	20.2	MIN	7.6	MIN	37.1
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.83	AVG	2.92	AVG	2.78
			MAX	3.15	MAX	3.05	MAX	2.89
			MIN	2.56	MIN	2.74	MIN	2.66
Conductivity	UMHOS/cm	SM 2510 B	AVG	261	AVG	265	AVG	295
			MAX	261	MAX	265	MAX	295
			MIN	261	MIN	265	MIN	295
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	33.2	AVG	25.1	AVG	38.9
			MAX	45.3	MAX	28.2	MAX	43.5
			MIN	19.2	MIN	22.5	MIN	32.6
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04	AVG	0.04
			MAX	0.19	MAX	0.08	MAX	0.10
			MIN	0.03	MIN	0.02	MIN	0.02