

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 4/1/2020 - 4/30/2020

Parameter	Units		Davis WTP		Ullrich WTP		Handcox WTP
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6
		Max	9.7	Max	9.7	Max	9.7
		Min	9.6	Min	9.6	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	61	Avg	57	Avg	71
		Max	64	Max	60	Max	75
		Min	56	Min	53	Min	68
Total Hardness	mg/L as CaCO3	Avg	91	Avg	88	Avg	94
		Max	93	Max	91	Max	98
		Min	85	Min	83	Min	90
Total Chloramines	mg/L	Avg	2.94	Avg	2.76	Avg	2.78
		Max	3.05	Max	2.90	Max	2.90
		Min	2.85	Min	2.65	Min	2.70
Total Organic Carbon	mg/L	Avg	2.52	Avg	2.22	Avg	2.44
		Max	2.64	Max	2.30	Max	2.54
		Min	2.38	Min	2.10	Min	2.36
Total Trihalomethanes	ug/L	Avg	27.2	Avg	28.9	Avg	26.1
		Max	27.9	Max	28.9	Max	26.1
		Min	26.5	Min	28.9	Min	26.1
Turbidity	NTU	Avg	0.04	Avg	0.03	Avg	0.04
		Max	0.06	Max	0.05	Max	0.06
		Min	0.03	Min	0.03	Min	0.03

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.