

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 6/1/2020 - 6/30/2020

Parameter	Units		Davis WTP		Ullrich WTP		Handcox WTP
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6
		Max	9.7	Max	9.8	Max	9.7
		Min	9.6	Min	9.5	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	61	Avg	55	Avg	62
		Max	65	Max	58	Max	66
		Min	54	Min	50	Min	58
Total Hardness	mg/L as CaCO3	Avg	88	Avg	82	Avg	84
		Max	92	Max	85	Max	88
		Min	81	Min	78	Min	80
Total Chloramines	mg/L	Avg	2.86	Avg	2.68	Avg	2.76
		Max	3.05	Max	2.78	Max	2.90
		Min	2.70	Min	2.55	Min	2.60
Total Organic Carbon	mg/L	Avg	2.36	Avg	2.13	Avg	2.21
		Max	2.48	Max	2.24	Max	2.28
		Min	2.18	Min	1.97	Min	2.12
Total Trihalomethanes	ug/L	Avg	32.1	Avg	32.0	Avg	30.7
		Max	33.4	Max	32.0	Max	30.7
		Min	30.7	Min	32.0	Min	30.7
Turbidity	NTU	Avg	0.04	Avg	0.01	Avg	0.03
		Max	0.07	Max	0.02	Max	0.05
		Min	0.02	Min	0.01	Min	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.