

Drinking Water Quality Report
Date Range: 01-NOV-2018 to 30-NOV-2018

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.2	AVG	9.5	AVG	9.6
			MAX	9.6	MAX	9.7	MAX	9.7
			MIN	8.1	MIN	9.2	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	49	AVG	49	AVG	53
			MAX	59	MAX	59	MAX	60
			MIN	41	MIN	31	MIN	41
Total Hardness	MG/L	SM 2340 C	AVG	75	AVG	76	AVG	73
			MAX	82	MAX	84	MAX	80
			MIN	69	MIN	63	MIN	60
Total Solids	MG/L	SM 2540 B	AVG	131	AVG	139	AVG	159
			MAX	142	MAX	154	MAX	178
			MIN	118	MIN	116	MIN	130
Chloramines	MG/L	SM 4500-CL F	AVG	2.81	AVG	2.77	AVG	2.86
			MAX	3.00	MAX	3.00	MAX	3.15
			MIN	2.50	MIN	2.55	MIN	2.70
Sulfate	MG/L	SM 4500-SO4 E	AVG	29.8	AVG	27.4	AVG	26.0
			MAX	29.9	MAX	27.4	MAX	26.0
			MIN	29.8	MIN	27.4	MIN	26.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.77	AVG	2.88	AVG	2.87
			MAX	3.16	MAX	3.29	MAX	3.16
			MIN	2.18	MIN	2.42	MIN	2.74
Conductivity	UMHOS/cm	SM 2510 B	AVG	243	AVG	244	AVG	283
			MAX	261	MAX	279	MAX	303
			MIN	232	MIN	215	MIN	271
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	36.2	AVG	28.6	AVG	46.4
			MAX	51.9	MAX	41.0	MAX	54.3
			MIN	22.0	MIN	20.4	MIN	34.5
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04	AVG	0.03
			MAX	0.18	MAX	0.09	MAX	0.06
			MIN	0.04	MIN	0.02	MIN	0.01