

Drinking Water Quality Report
Date Range: 01-JUL-2011 to 31-JUL-2011

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.7
			MAX	10.0	MAX	9.8
			MIN	9.7	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	67	AVG	65
			MAX	74	MAX	69
			MIN	63	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	92	AVG	91
			MAX	99	MAX	96
			MIN	88	MIN	87
Total Solids	MG/L	SM 2540 B	AVG	158	AVG	153
			MAX	164	MAX	158
			MIN	153	MIN	148
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.63	AVG	2.52
			MAX	2.82	MAX	2.75
			MIN	2.40	MIN	2.00
Sulfate	MG/L	SM 4500-SO4 E	AVG	27.5	AVG	27.7
			MAX	27.6	MAX	27.7
			MIN	27.4	MIN	27.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.27	AVG	2.10
			MAX	2.38	MAX	2.19
			MIN	2.17	MIN	2.02
Conductivity	UMHOS/cm	SM 2510 B	AVG	286	AVG	282
			MAX	289	MAX	282
			MIN	283	MIN	282
Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	42.2	AVG	30.5
			MAX	52.4	MAX	30.7
			MIN	36.1	MIN	30.3
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03
			MAX	0.10	MAX	0.05
			MIN	0.03	MIN	0.02