

Drinking Water Quality Report  
Date Range: 01-JAN-2013 to 31-JAN-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.7
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	80	AVG	80
			MAX	86	MAX	86
			MIN	72	MIN	66
Total Hardness	MG/L	SM 2340 C	AVG	115	AVG	116
			MAX	122	MAX	122
			MIN	108	MIN	103
Total Solids	MG/L	SM 2540 B	AVG	188	AVG	183
			MAX	198	MAX	206
			MIN	174	MIN	164
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.69	AVG	2.55
			MAX	2.85	MAX	2.75
			MIN	2.60	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.2	AVG	42.2
			MAX	35.6	MAX	42.2
			MIN	34.8	MIN	42.2
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.78	AVG	2.81
			MAX	3.03	MAX	2.98
			MIN	2.56	MIN	2.71
Conductivity	UMHOS/cm	SM 2510 B	AVG	369	AVG	366
			MAX	380	MAX	386
			MIN	354	MIN	345
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	31.6	AVG	32.7
			MAX	33.2	MAX	35.0
			MIN	30.2	MIN	30.7
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.09	MAX	0.07
			MIN	0.05	MIN	0.02