

Drinking Water Quality Report
Date Range: 01-OCT-2013 to 31-OCT-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.3	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	59	AVG	58
			MAX	68	MAX	70
			MIN	52	MIN	48
Total Hardness	MG/L	SM 2340 C	AVG	96	AVG	98
			MAX	105	MAX	105
			MIN	88	MIN	89
Total Solids	MG/L	SM 2540 B	AVG	200	AVG	203
			MAX	218	MAX	222
			MIN	182	MIN	190
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.84	AVG	2.64
			MAX	3.05	MAX	2.80
			MIN	2.55	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	38.3	AVG	34.6
			MAX	39.9	MAX	34.6
			MIN	36.7	MIN	34.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.70	AVG	2.67
			MAX	2.97	MAX	2.93
			MIN	2.43	MIN	2.34
Conductivity	UMHOS/cm	SM 2510 B	AVG	343	AVG	343
			MAX	346	MAX	343
			MIN	339	MIN	343
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	41.9	AVG	50.4
			MAX	52.1	MAX	52.6
			MIN	36.5	MIN	46.9
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.05
			MAX	0.04	MAX	0.02
			MIN	0.15	MIN	0.12