

Drinking Water Quality Report
Date Range: 01-MAY-2014 to 31-MAY-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	9.8
			MIN	9.4	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	64	AVG	65
			MAX	75	MAX	71
			MIN	57	MIN	60
Total Hardness	MG/L	SM 2340 C	AVG	101	AVG	102
			MAX	108	MAX	108
			MIN	93	MIN	97
Total Solids	MG/L	SM 2540 B	AVG	199	AVG	205
			MAX	207	MAX	222
			MIN	186	MIN	186
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.59	AVG	2.51
			MAX	2.95	MAX	2.65
			MIN	2.35	MIN	2.20
Sulfate	MG/L	SM 4500-SO4 E	AVG	36.6	AVG	39.7
			MAX	36.9	MAX	39.7
			MIN	36.2	MIN	39.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.83	AVG	2.77
			MAX	3.06	MAX	2.86
			MIN	2.58	MIN	2.68
Conductivity	UMHOS/cm	SM 2510 B	AVG	359	AVG	371
			MAX	360	MAX	371
			MIN	357	MIN	371
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	36.5	AVG	40.8
			MAX	44.0	MAX	43.0
			MIN	30.6	MIN	38.3
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.04
			MAX	0.12	MAX	0.08
			MIN	0.03	MIN	0.03