

Drinking Water Quality Report
Date Range: 01-OCT-2014 to 31-OCT-2014

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	9.8
			MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	57	AVG	56
			MAX	61	MAX	60
			MIN	52	MIN	51
Total Hardness	MG/L	SM 2340 C	AVG	92	AVG	91
			MAX	95	MAX	94
			MIN	87	MIN	87
Total Solids	MG/L	SM 2540 B	AVG	158	AVG	161
			MAX	180	MAX	182
			MIN	142	MIN	140
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.79	AVG	2.76
			MAX	3.05	MAX	3.00
			MIN	2.20	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	36.8	AVG	37.6
			MAX	37.2	MAX	37.6
			MIN	36.3	MIN	37.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.95	AVG	2.81
			MAX	3.15	MAX	2.96
			MIN	2.72	MIN	2.61
Conductivity	UMHOS/cm	SM 2510 B	AVG	325	AVG	326
			MAX	327	MAX	326
			MIN	322	MIN	326
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	56.1	AVG	42.4
			MAX	61.9	MAX	48.7
			MIN	48.1	MIN	31.2
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03
			MAX	0.11	MAX	0.05
			MIN	0.03	MIN	0.02