

Drinking Water Quality Report
Date Range: 01-APR-2015 to 30-APR-2015

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.4	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	49	AVG	53
			MAX	56	MAX	60
			MIN	42	MIN	47
Total Hardness	MG/L	SM 2340 C	AVG	102	AVG	108
			MAX	108	MAX	115
			MIN	98	MIN	103
Total Solids	MG/L	SM 2540 B	AVG	186	AVG	197
			MAX	212	MAX	220
			MIN	168	MIN	176
Chloramines	MG/L	SM 4500-CL F	AVG	2.62	AVG	2.54
			MAX	2.90	MAX	2.70
			MIN	2.50	MIN	2.35
Sulfate	MG/L	SM 4500-SO4 E	AVG	52.5	AVG	52.0
			MAX	53.0	MAX	52.0
			MIN	51.9	MIN	52.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.32	AVG	2.35
			MAX	2.50	MAX	2.44
			MIN	2.23	MIN	2.28
Conductivity	UMHOS/cm	SM 2510 B	AVG	372	AVG	388
			MAX	374	MAX	388
			MIN	370	MIN	388
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	40.9	AVG	42.9
			MAX	46.8	MAX	47.7
			MIN	35.8	MIN	38.9
Turbidity	NTU	SM 2130 B	AVG	0.04	AVG	0.02
			MAX	0.07	MAX	0.02
			MIN	0.03	MIN	0.01