

Drinking Water Quality Report
Date Range: 01-AUG-2015 to 31-AUG-2015

Parameter	Units	Method Cd	Davis WTP		Ullrich WTP		WTP 4	
				T2,T2H		T3		T4
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8	MAX	9.6
			MIN	9.5	MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	50	AVG	53	AVG	59
			MAX	56	MAX	59	MAX	64
			MIN	45	MIN	47	MIN	56
Total Hardness	MG/L	SM 2340 C	AVG	89	AVG	93	AVG	84
			MAX	94	MAX	99	MAX	88
			MIN	86	MIN	88	MIN	80
Total Solids	MG/L	SM 2540 B	AVG	175	AVG	189	AVG	167
			MAX	204	MAX	212	MAX	187
			MIN	136	MIN	174	MIN	148
Chloramines	MG/L	SM 4500-CL F	AVG	2.90	AVG	2.60	AVG	2.84
			MAX	3.15	MAX	2.95	MAX	3.05
			MIN	2.60	MIN	2.15	MIN	2.70
Sulfate	MG/L	SM 4500-SO4 E	AVG	39.0	AVG	39.0	AVG	36.0
			MAX	39.2	MAX	38.9	MAX	36.4
			MIN	39.1	MIN	38.9	MIN	36.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.58	AVG	2.56	AVG	2.40
			MAX	2.74	MAX	2.73	MAX	2.51
			MIN	2.40	MIN	2.32	MIN	2.31
Conductivity	UMHOS/cm	SM 2510 B	AVG	327	AVG	340	AVG	324
			MAX	328	MAX	340	MAX	324
			MIN	326	MIN	340	MIN	324
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	46.0	AVG	40.8	AVG	35.8
			MAX	53.8	MAX	46.8	MAX	39.3
			MIN	41.5	MIN	37.9	MIN	32.6
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02	AVG	0.03
			MAX	0.08	MAX	0.06	MAX	0.03
			MIN	0.03	MIN	0.02	MIN	0.02