

Drinking Water Quality Report
Date Range: 01-MAY-2015 to 31-MAY-2015

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.3	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	45	AVG	49
			MAX	58	MAX	61
			MIN	34	MIN	41
Total Hardness	MG/L	SM 2340 C	AVG	92	AVG	97
			MAX	108	MAX	110
			MIN	80	MIN	86
Total Solids	MG/L	SM 2540 B	AVG	169	AVG	177
			MAX	184	MAX	214
			MIN	154	MIN	136
Chloramines	MG/L	SM 4500-CL F	AVG	2.65	AVG	2.47
			MAX	2.90	MAX	2.60
			MIN	2.45	MIN	2.20
Sulfate	MG/L	SM 4500-SO4 E	AVG	No Sample	AVG	49.2
			MAX	No Sample	MAX	49.2
			MIN	No Sample	MIN	49.2
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.52	AVG	2.54
			MAX	2.66	MAX	2.78
			MIN	2.42	MIN	2.30
Conductivity	UMHOS/cm	SM 2510 B	AVG	No Sample	AVG	374
			MAX	No Sample	MAX	374
			MIN	No Sample	MIN	374
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	54.4	AVG	50.3
			MAX	57.7	MAX	60.3
			MIN	51.1	MIN	36.1
Turbidity	NTU	SM 2130 B	AVG	0.05	AVG	0.02
			MAX	0.08	MAX	0.04
			MIN	0.03	MIN	0.02