

Drinking Water Quality Report
Date Range: 01-JUN-2016 to 30-JUN-2016

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8	MAX	9.6
			MIN	9.6	MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	60	AVG	54	AVG	67
			MAX	67	MAX	60	MAX	72
			MIN	53	MIN	48	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	86	AVG	81	AVG	89
			MAX	98	MAX	93	MAX	100
			MIN	78	MIN	74	MIN	84
Total Solids	MG/L	SM 2540 B	AVG	127	AVG	117	AVG	141
			MAX	139	MAX	124	MAX	154
			MIN	120	MIN	110	MIN	123
Chloramines	MG/L	SM 4500-CL F	AVG	2.65	AVG	2.55	AVG	2.59
			MAX	2.90	MAX	2.75	MAX	3.05
			MIN	2.50	MIN	2.35	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	32.0	AVG	30.0	AVG	39.0
			MAX	33.6	MAX	30.0	MAX	38.5
			MIN	30.5	MIN	30.0	MIN	38.5
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.97	AVG	2.64	AVG	2.79
			MAX	3.13	MAX	2.77	MAX	2.93
			MIN	2.63	MIN	2.41	MIN	2.63
Conductivity	UMHOS/cm	SM 2510 B	AVG	278	AVG	270	AVG	304
			MAX	279	MAX	270	MAX	304
			MIN	276	MIN	270	MIN	304
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	52.6	AVG	45.9	AVG	39.2
			MAX	61.7	MAX	48.5	MAX	47.8
			MIN	42.7	MIN	43.4	MIN	33.4
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03	AVG	0.05
			MAX	0.14	MAX	0.04	MAX	0.09
			MIN	0.05	MIN	0.02	MIN	0.03