

Drinking Water Quality Report
Date Range: 01-MAR-2016 to 31-MAR-2016

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6	AVG	9.5
			MAX	9.9	MAX	9.8	MAX	9.6
			MIN	9.4	MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	48	AVG	54	AVG	75
			MAX	53	MAX	61	MAX	79
			MIN	44	MIN	47	MIN	70
Total Hardness	MG/L	SM 2340 C	AVG	90	AVG	99	AVG	100
			MAX	98	MAX	106	MAX	107
			MIN	84	MIN	87	MIN	94
Total Solids	MG/L	SM 2540 B	AVG	141	AVG	147	AVG	154
			MAX	178	MAX	185	MAX	180
			MIN	106	MIN	84	MIN	126
Chloramines	MG/L	SM 4500-CL F	AVG	2.63	AVG	2.57	AVG	2.59
			MAX	2.85	MAX	2.75	MAX	2.80
			MIN	2.45	MIN	2.30	MIN	2.48
Sulfate	MG/L	SM 4500-SO4 E	AVG	48.0	AVG	45.0	AVG	28.0
			MAX	49.6	MAX	45.2	MAX	27.7
			MIN	45.9	MIN	45.2	MIN	27.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.55	AVG	2.50	AVG	2.91
			MAX	2.87	MAX	2.74	MAX	3.02
			MIN	2.42	MIN	2.38	MIN	2.82
Conductivity	UMHOS/cm	SM 2510 B	AVG	312	AVG	330	AVG	325
			MAX	317	MAX	330	MAX	325
			MIN	306	MIN	330	MIN	325
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	39.0	AVG	45.0	AVG	37.0
			MAX	54.4	MAX	49.6	MAX	39.4
			MIN	13.7	MIN	38.8	MIN	31.5
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03	AVG	0.06
			MAX	0.11	MAX	0.05	MAX	0.09
			MIN	0.05	MIN	0.02	MIN	0.03