

Building a Better and Safer Austin Together

Building Temporary Certificate of Occupancy (TCO) Inspections Checklist

Commercial Inspections

<u>DevelopmentATX.com</u> | Phone: 311 (or 512-974-2000 outside Austin) For submittal and fee information, see <u>austintexas.gov/digitaldevelopment</u>

| This checklist is provided as a reference tool, and it is not intended to be exhaustive of all p requirements Please refer to the latest adopted International Building Code (IBC), International Energy Conservation Code (I.E.C.C) Local Amendments to the In Residential Code (IRC-LA), I.E.C.C (IECC-LA), the City of Austin Building Criteria Manual (Plumbing Code (UPC), the City of Austin Land Development Code (LDC), and the National (NEC) for code sections listed below. □ IRC, IECC and IBC https://codes.iccsafe.org/public/collections/I-Codes □ Local amendments https://library.municode.com/TX/Austin □ UPC and UMC https://www.nfpa.org/ □ NEC https://www.nfpa.org/ | onal Residential nternational (BCM), the Uniform |
|--|--|
| Please verify the following before scheduling the inspection: | |
| 108 Stocking | |
| □ The contractor or person doing the work has reviewed the approved plans and can ensiconstruction being inspected is consistent and ready for inspection. □ Job address is posted in a visible location. <i>IBC (F)502.1</i> □ Contractor has a set of "approved plans," either electronic or paper, on site. <i>IBC 107.3.1</i> □ Mechanical, electric, plumbing, and fire have passed TCO inspection. □ TCO fee has been paid. <i>IBC Section 109.1</i> | |
| 109 Occupancy | |
| □ The contractor or person doing the work has reviewed the approved plans and can ensiconstruction being inspected is consistent and ready for inspection. □ Job address is posted in a visible location. <i>IBC (F)502.1</i> □ Contractor has a set of "approved plans," either electronic or paper, on site. <i>IBC 107.3</i>. □ Mechanical, electric, plumbing, and fire have passed TCO inspection. □ TCO fee has been paid. <i>IBC Section 109.1</i> □ All required one-time inspections (environmental, landscape, etc.) have passed TCO or There is no ceiling below the required height. <i>IBC section 1003.2</i> □ Doors, when fully opened, do not reduce the required width by more than 7 inches. <i>IBC 1005.7.1</i> □ Doors, in any position, do not reduce the required width by more than one-half. <i>IBC sec Building includes all required exits</i>, exit access doorways, exit access stairways or rample combination thereof. <i>IBC section 1007.1.1</i> □ Building includes all required stairways between stories. <i>IBC section 1009.3</i> □ The capacity of each door opening is sufficient for the occupant load. <i>IBC section 1010</i> □ All life safety requirements are met. □ A readily visible, durable sign is posted on the egress side, on or adjacent to the door, so the province of the province of | final. C section ction 1005.7.1 ps, or any |

o The sign is in letters 1 inch high on a contrasting background. IBC section 1010.2.4(3)

(3.2)

DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED.