



# Electrical Temporary Certificate of Occupancy (TCO) Inspection Checklist Commercial Inspections

[DevelopmentATX.com](http://DevelopmentATX.com) | Phone: 311 (or 512-974-2000 outside Austin)  
For submittal and fee information, see [austintexas.gov/digitaldevelopment](http://austintexas.gov/digitaldevelopment)

This checklist is provided as a reference tool, and it is not intended to be exhaustive of all possible requirements. Please refer to the latest adopted International Building Code (IBC), International Residential Code (IRC), International Energy Conservation Code (I.E.C.C) Local Amendments to the International Residential Code (IRC-LA), I.E.C.C (IECC-LA), the City of Austin Building Criteria Manual (BCM), the Uniform Plumbing Code (UPC), the City of Austin Land Development Code (LDC), and the National Electric Code (NEC) for code sections listed below.

- IRC, IECC and IBC <https://codes.iccsafe.org/public/collections/I-Codes>
- Local amendments <https://library.municode.com/TX/Austin>
- UPC and UMC <http://www.iapmo.org/>
- NEC <https://www.nfpa.org/>

***Please verify the following before scheduling the inspection:***

## 306 Occupancy

- All life-safety equipment and luminaires have been installed, connected, and are functioning.
- Electrical distribution has been inspected.
- Electrical equipment, devices, and luminaires that are not yet installed have been covered, locked out, and made safe.

## 307 Stocking

- Electrical Rough-in inspections have been completed.