



# Plumbing Gas Rough Inspection Checklist

## Commercial Inspections

DevelopmentATX.com | Phone: 311 (or 512-974-2000 outside Austin)  
For submittal and fee information, see [austintexas.gov/digitaldevelopment](http://austintexas.gov/digitaldevelopment)

This checklist is provided as a reference tool, and it is not intended to be exhaustive of all possible requirements. Please refer to the latest adopted International Building Code (IBC), International Residential Code (IRC), International Energy Conservation Code (I.E.C.C) Local Amendments to the International Residential Code (IRC-LA), I.E.C.C (IECC-LA), the City of Austin Building Criteria Manual (BCM), the Uniform Plumbing Code (UPC), the City of Austin Land Development Code (LDC), and the National Electric Code (NEC) for code sections listed below.

- IRC, IECC and IBC <https://codes.iccsafe.org/public/collections/I-Codes>
- Local amendments <https://library.municode.com/TX/Austin>
- UPC and UMC <http://www.iapmo.org/>
- NEC <https://www.nfpa.org/>

**Please verify the following before scheduling the inspection:**

### 503 Gas Rough

- The contractor or person doing the work has reviewed the approved plans and can ensure that the construction being inspected is consistent and ready for inspection.
- Job address is posted in a visible location. *IBC 501.2*
- Contractor has a set of “approved plans,” either electronic or paper, on site. *UPC 104.4.6*
- All materials used are listed and approved. *UPC 1208.5-1208.5.3.4*
- All installed piping has been air tested using approved methods. *UPC 1203.3.1 (Local Amendment)*
- All supports and hangers are approved for use and installed at required locations. *UPC Table 1210.2.4.1*
- All installed piping has been sized correctly based on the Btu requirements. *UPC 1208.4*