



## §6-4-10 Annual Vehicle Wash Equipment Evaluation Form:

***\*\*Inspection must be performed by a plumber licensed by the State of Texas\*\****

Name of Facility: \_\_\_\_\_ Water Meter: # \_\_\_\_\_

Address: \_\_\_\_\_ Zip Code: # \_\_\_\_\_

Contact Person: \_\_\_\_\_ Phone: # \_\_\_\_\_

### Rule #: R161-13.16

- |      |      |     |   |
|------|------|-----|---|
| Pass | Fail |     | (a) No leaks are present in wash equipment.   |
| Pass | Fail | N/A | (b) In-bay, hand-held spray wash equipment, including a spray wand or foaming brush, does not use more than 3.5 gallons of water a minute and has a trigger shutoff and protective weep.  |
| Pass | Fail | N/A | (c) Portable pressure wash equipment must have a spray nozzle with a positive shut off and protective weep mechanism and shall not use more than the following: <ul style="list-style-type: none"> <li>• 3.5 gallons of water a minute for passenger vehicles including automobiles, delivery vans and buses; or</li> <li>• 10.0 gallons of water a minute for commercial equipment vehicles such as front-end loaders, dump trucks, earth movers or other similar equipment</li> </ul> |
| Pass | Fail | N/A | (d) A conveyor or drive through friction system does not use more than 35 gallons for each vehicle.   |
| Pass | Fail | N/A | (e) A conveyor or drive through touchless system does not use more than 35 gallons for each vehicle.  |
| Pass | Fail | N/A | (f) An in bay rollover automatic system does not use more than 75 gallons per vehicle for buses and other similar large vehicles.   |
| Pass | Fail | N/A | (g) An in bay rollover automatic system does not use more than 45 gallons per vehicle.  |
| Pass | Fail | N/A | (h) Each chamois wringer has a positive shutoff valve.  |
| Pass | Fail | N/A | (i) A system using reverse osmosis rinse water must reclaim, and reuse, reject water.   |

**Please fill out the worksheet on the back of this page with the results of the testing performed. The audit form will not be accepted without a completed worksheet.**

Comments:

Spray wand	GPM	Trigger shutoff
Bay 1		
Bay 2		
Bay 3		
Bay 4		
Bay 5		
Bay 6		
Bay 7		
Bay 8		
Bay 9		
Bay 10		
Bay 11		
Bay 12		
Bay 13		
Bay 14		
Bay 15		

Foaming Brush	GPM	Trigger shutoff
Bay 1		
Bay 2		
Bay 3		
Bay 4		
Bay 5		
Bay 6		
Bay 7		
Bay 8		
Bay 9		
Bay 10		
Bay 11		
Bay 12		
Bay 13		
Bay 14		
Bay 15		

Portable Pressure Wash Equipment	GPM	Trigger shutoff
Unit 1		
Unit 2		
Unit 3		
Unit 4		
Unit 5		
Unit 6		
Unit 7		
Unit 8		
Unit 9		
Unit 10		
Unit 11		
Unit 12		
Unit 13		
Unit 14		
Unit 15		

Conveyor Touchless System	GPV
System 1	
System 2	
System 3	
System 4	
System 5	
System 6	
System 7	
System 8	
System 9	
System 10	

Conveyor Friction System	GPV
System 1	
System 2	
System 3	
System 4	
System 5	
System 6	
System 7	
System 8	
System 9	
System 10	

Rollover Automatic System	GPV
System 1	
System 2	
System 3	
System 4	
System 5	
System 6	
System 7	
System 8	
System 9	
System 10	

*This section signed by inspecting plumber*

***I hereby certify the inspection results provided on this form are true and accurately reflect my findings:***

Company Name: \_\_\_\_\_ Title: \_\_\_\_\_

E-mail Address: \_\_\_\_\_ Phone Number: \_\_\_\_\_

Printed Name: \_\_\_\_\_ License No: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Return completed forms to:**

City of Austin Water Conservation Office  
P.O. Box 1088  
Austin, TX 78767

Email: [FacEvalSubmit@austintexas.gov](mailto:FacEvalSubmit@austintexas.gov)

Fax: 512/974-3504